



Environmental and Laboratory Services

Dover Location:
90 1/2 West Blackwell St., Dover, NJ 07801
Phone: (973) 989-0010, Fax (973) 989-0156

Marlboro Location:
8A Railroad Ave, Marlboro, NJ 07746
Phone: (732) 308-3500, Fax (732) 308-3503

Date: February 18, 2022
Client: Jefferson Township BOE
Address: 31 NJ-181
Lake Hopatcong, NJ 07849

PWSID#:
Project Location: 2 Francine Place, Oak Ridge

Analytical Results

Table with sample details: Sample Matrix (Drinking Water), Sample Location (Field Blank), Sampled By (C. Anzolut), Sample Date/Time (2/2/2022 6:07), Lab Sample Number (220201007-001), Customer Sample Number.

Table with 10 columns: Parameters, Method, Results, Units, NJDEP Limit, Date Analyzed, Time Analyzed, Analyst, Reporting Limit, Dilution Factor. Row 1: Lead-1st Draw, SM3113B, <2.00, ug/L, 15, 2/11/2022, 22:40, JGW, 2, 1.

Table with sample details: Sample Matrix (Drinking Water), Sample Location (JTWR-POE-AWING-KC-3BAY SINK LEFT-1), Sampled By (C. Anzolut), Sample Date/Time (2/2/2022 6:08), Lab Sample Number (220201007-002), Customer Sample Number.

Table with 10 columns: Parameters, Method, Results, Units, NJDEP Limit, Date Analyzed, Time Analyzed, Analyst, Reporting Limit, Dilution Factor. Row 1: Lead-1st Draw, SM3113B, 11.9, ug/L, 15, 2/11/2022, 20:23, JGW, 2, 1.

Sample Matrix: Drinking Water		Lab Sample Number: 220201007-007							
Sample Location: JTWR-TL-DW-6		Customer Sample Number:							
Sampled By: C. Anzolut									
Sample Date/Time: 2/2/2022 6:15									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	3.05	µg/L	15	2/11/2022	21:05	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220201007-009							
Sample Location: JTWR-RMA14-DW-8		Customer Sample Number:							
Sampled By: C. Anzolut									
Sample Date/Time: 2/2/2022 6:20									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
1st Draw	SM3113B	13.4	µg/L	15	2/11/2022	21:16	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220201007-011							
Sample Location: JTWR-RMA12-AWING-DW-10		Customer Sample Number:							
Sampled By: C. Anzolut									
Sample Date/Time: 2/2/2022 6:23									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	19.2 **	µg/L	15	2/11/2022	21:22	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220201007-013							
Sample Location: JTWR-RMA10-AWING-DW-12		Customer Sample Number:							
Sampled By: C. Anzolut									
Sample Date/Time: 2/2/2022 6:29									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	6.71	µg/L	15	2/11/2022	21:27	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220201007-019							
Sample Location:	JTWR-HT-BREEZY HALL-LEFT-WF-18	Customer Sample Number:								
Sampled By:	C. Anzolut									
Sample Date/Time:	2/2/2022 6:21									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor	
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	2/11/2022	22:17	JGW	2	1	

Sample Matrix:	Drinking Water	Lab Sample Number:	220201007-020							
Sample Location:	JTWR-HT-BREEZY HALL-RIGHT-WF-19	Customer Sample Number:								
Sampled By:	C. Anzolut									
Sample Date/Time:	2/2/2022 6:20									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor	
1st Draw	SM3113B	5.45	µg/L	15	2/11/2022	22:23	JGW	2	1	

Sample Matrix:	Drinking Water	Lab Sample Number:	220201007-021							
Sample Location:	JTWR-HT-BREEZY HALL-LEFT-BF2	Customer Sample Number:								
Sampled By:	C. Anzolut									
Sample Date/Time:	2/2/2022 6:13									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor	
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	2/11/2022	22:28	JGW	2	1	

Sample Matrix:	Drinking Water	Lab Sample Number:	220201007-022							
Sample Location:	JTWR-CWING-HALL CHILLER	Customer Sample Number:								
Sampled By:	C. Anzolut									
Sample Date/Time:	2/2/2022 6:52									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor	
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	2/11/2022	23:02	JGW	2	1	

Jefferson Township BOE

NJ Lab ID# 14013 (Dover)

NJ Lab ID# 13033 (Marlboro)

** Result does not meet NJDEP Limits.

NJDEP Limit for free and/or total chlorine does not apply to non-chlorinated samples.

Any method followed by an asterisk (*) was analyzed by the Agra-Marlboro laboratory.

All other methods, unless otherwise specified, were analyzed by the Agra-Dover laboratory.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan VanVeen

Susan VanVeen, Laboratory Manager

February 18, 2022



CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

2003010
22020

Customer Name: Jefferson Township BOE
 Location: 2 Francine Place, Oak Ridge
 Address: 31 NJ-181
 Lake Hopatcong, NJ, 07849

Customer Contact: Nick
 Phone: Work/Cell 973-663-5780 / 973-214-6997

Report to: Jefferson Township BOE
 31 NJ-181
 Lake Hopatcong, NJ, 07849
 jjahnke@jefftwp.org

Agra Environmental Services
 90 1/2 West Blackwell Street
 Dover, NJ 07801
 Phone: (973) 989-0010
 Fax: (973) 989-0156

Matrix Abbreviations: DW - Drinking water, GW - Ground Water, RAW-GW - DW RAW GW, WW/NP/ - Wastewater, SL - Sludge
 P - Pool, L - Lake
 Page 2 of 3

Project: White Rock Elementary
 Collection: PWSID#
 for laboratory use only
 Field Analysis

Sample ID	Location	Date	Time	Lab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED
0201007-011	JTWR-RMA12-AWING-DW-10	2/2/20	0633	X	DW	DW	1	HN03	Lead-1st Draw
0201007-012	JTWR-RMA10-AWING-DWB-11	out of Service		X	DW	DW	1	HN03	Lead-1st Draw
0201007-013	JTWR-RMA10-AWING-DW-12	0629		X	DW	DW	1	HN03	Lead-1st Draw
0201007-014	JTWR-BWING-COM. LAB-WF-13	0630		X	DW	DW	1	HN03	Lead-1st Draw
0201007-015	JTWR-BWING-G&B-LEFT WF-14	0630		X	DW	DW	1	HN03	Lead-1st Draw
0201007-016	JTWR-BWING-G&B-RIGHT-WF-1	0636		X	DW	DW	1	HN03	Lead-1st Draw
0201007-017	JTWR-BWING-BREEZY HALL-LEF	0646		X	DW	DW	1	HN03	Lead-1st Draw
0201007-018	JTWR-BING BREEZY HALL-RIGH	out of Service		X	DW	DW	1	HN03	Lead-1st Draw
0201007-019	JTWR-HT-BREEZY HALL-LEFT-W	0621		X	DW	DW	1	HN03	Lead-1st Draw
0201007-020	JTWR-HT-BREEZY HALL-RIGHT-	0620		X	DW	DW	1	HN03	Lead-1st Draw

Are these samples for compliance? (circle one): Yes or **(No)**
 Indicate laboratory location where analysis request was performed
 NJDEP Laboratory Certification (Dover, NJ) #14013
 NJDEP Laboratory Certification (Marlboro, NJ) #13033
 Cooler Temperature Upon Receipt at Lab: 21A

Reporting Requirements (Check Box): Standard NJ Reduced Other (Specify)

Sample Custody Exchanges (Please use full legal signature)
 Released By: [Signature] Date: 2/2/20 Time: 1602
 Received By: [Signature] Date: 2/2/20 Time: 1700

Is sample known to be hazardous? (circle one) Yes or No