Agra

Environmental and Laboratory Services

Dover Location:
90 1/2 West Blackwell St., Dover, NJ 07801
Phone: (973) 989-0010, Fax (973) 989-0156

Marlboro Location:
8A Railroad Ave, Marlboro, NJ 07746
Phone: (732) 308-3500, Fax (732) 308-3503

Analytical Results

Date: February 28, 2022
Client: Jefferson Township BOE
Address: 31 NJ-181
Lake Hopatcong, NJ 07849

PWSID#:
Project Location: 205 Cozy Lake Road

Sample Matrix: Drinking Water
Sample Location: Field Blank
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 6:02

Lab Sample Number: 211026039-001
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	2/24/2022	20:14	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTCL-POE-TAP
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 6:03

Lab Sample Number: 211026039-002
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	18.0 **	µg/L	15	2/24/2022	12:15	JGW	2	1

ıple Matrix: Drinking Water
Sample Location: JTCL-WF-Hall-L-2
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 6:05

Lab Sample Number: 211026039-003
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	4.29	µg/L	15	2/24/2022	12:21	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTCL-WF-Hall-R-3
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 6:06

Lab Sample Number: 211026039-004
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
ⁱ-1st Draw	SM3113B	11.4	µg/L	15	2/24/2022	12:26	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTCL-FP-KC-3Baysink-4
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 6:08

Lab Sample Number: 211026039-005
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	2/24/2022	12:32	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTCL-HW-KC-5
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 6:09

Lab Sample Number: 211026039-006
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	8.37	µg/L	15	2/24/2022	12:37	JGW	2	1

ıple Matrix: Drinking Water
Sample Location: JTCL-NS-Sink-1-6
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 6:13

Lab Sample Number: 211026039-007
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	3.94	µg/L	15	2/24/2022	12:43	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTCL-NS-BR-Sink-2-7
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 6:14

Lab Sample Number: 211026039-008
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
¹-1st Draw	SM3113B	< 2.00	µg/L	15	2/24/2022	12:48	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTCL-DWB-RM107-8
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 6:19

Lab Sample Number: 211026039-009
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	14.6	µg/L	15	2/24/2022	12:54	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTCL-DW-RM107-9
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 6:20

Lab Sample Number: 211026039-010
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	17.1 **	µg/L	15	2/24/2022	13:16	JGW	2	1

ıple Matrix: Drinking Water
Sample Location: JTCL-DWB-RM108-10
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 6:23

Lab Sample Number: 211026039-011
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	14.7	µg/L	15	2/24/2022	13:21	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTCL-DW-RM108-11
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 6:24

Lab Sample Number: 211026039-012
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
ˡ-1st Draw	SM3113B	< 2.00	µg/L	15	2/24/2022	13:27	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTCL-WF-Hall-Boys RM-L-12
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 6:26

Lab Sample Number: 211026039-013
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	2/24/2022	13:32	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTCL-WF-Hall-Girls RM-R-13
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 6:27

Lab Sample Number: 211026039-014
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	5.23	µg/L	15	2/24/2022	13:38	JGW	2	1

ıple Matrix: Drinking Water
Sample Location: JTCL-DWB-RM109-14
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 6:33

Lab Sample Number: 211026039-015
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	77.5 **	µg/L	15	2/24/2022	13:49	JGW	2	4

Sample Matrix: Drinking Water
Sample Location: JTCL-DW-RM109-15
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 6:34

Lab Sample Number: 211026039-016
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
-1st Draw	SM3113B	2.32	µg/L	15	2/24/2022	13:55	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTCL-DWB-RM110-16
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 6:35

Lab Sample Number: 211026039-017
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	13.0	µg/L	15	2/24/2022	14:00	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTCL-DW-RM110-17
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 6:36

Lab Sample Number: 211026039-018
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	15.9 **	µg/L	15	2/24/2022	14:22	JGW	2	1

ıple Matrix: Drinking Water
Sample Location: JTCL-DWB-RM101-18
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 6:39

Lab Sample Number: 211026039-019
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	13.9	µg/L	15	2/24/2022	14:27	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTCL-DW-RM101-19
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 6:40

Lab Sample Number: 211026039-020
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
ł-1st Draw	SM3113B	4.54	µg/L	15	2/24/2022	15:00	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTCL-DWB-RM102-20
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 6:43

Lab Sample Number: 211026039-021
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	8.80	µg/L	15	2/24/2022	15:05	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTCL-DWB-RM111-22
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 6:47

Lab Sample Number: 211026039-023
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	3.74	µg/L	15	2/24/2022	15:11	JGW	2	1

ıple Matrix: Drinking Water
Sample Location: JTCL-DW-RM111-23
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 6:48

Lab Sample Number: 211026039-024
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	5.55	µg/L	15	2/24/2022	15:17	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTCL-DWB-RM112-24
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 6:52

Lab Sample Number: 211026039-025
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
l-1st Draw	SM3113B	5.06	µg/L	15	2/24/2022	15:22	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTCL-DWB-RM103-26
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 6:53

Lab Sample Number: 211026039-027
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	7.62	µg/L	15	2/24/2022	15:28	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTCL-DW-RM103-27
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 6:54

Lab Sample Number: 211026039-028
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	2/24/2022	15:44	JGW	2	1

ıple Matrix: Drinking Water
Sample Location: JTCL-DWB-RM104-28
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 6:57

Lab Sample Number: 211026039-029
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	2.19	µg/L	15	2/24/2022	15:49	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTCL-DW-RMB113-30
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 7:00

Lab Sample Number: 211026039-031
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
ł-1st Draw	SM3113B	16.5 **	µg/L	15	2/24/2022	16:00	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTCL-DW-RM113-31
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 7:01

Lab Sample Number: 211026039-032
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	3.40	µg/L	15	2/24/2022	16:06	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTCL-DWB-RM114-32
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 7:04

Lab Sample Number: 211026039-033
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	21.4 **	µg/L	15	2/24/2022	16:14	JGW	2	2

ıple Matrix: Drinking Water
Sample Location: JTCL-DW-RM114-33
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 7:05

Lab Sample Number: 211026039-034
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	5.09	µg/L	15	2/24/2022	16:20	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTCL-DWB-RM105-34
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 7:09

Lab Sample Number: 211026039-035
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
ı-1st Draw	SM3113B	3.86	µg/L	15	2/24/2022	16:25	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTCL-DW-RM105-35
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 7:10

Lab Sample Number: 211026039-036
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	3.27	µg/L	15	2/24/2022	16:31	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTCL-DWB-RM115-36
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 7:14

Lab Sample Number: 211026039-037
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	26.8 **	µg/L	15	2/24/2022	16:39	JGW	2	2

nple Matrix: Drinking Water
Sample Location: JTCL-DW-RM115-37
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 7:15

Lab Sample Number: 211026039-038
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	6.90	µg/L	15	2/24/2022	17:01	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTCL-DWB-RM116-38
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 7:18

Lab Sample Number: 211026039-039
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
d-1st Draw	SM3113B	53.9 **	µg/L	15	2/24/2022	17:12	JGW	2	4

Sample Matrix: Drinking Water
Sample Location: JTCL-DWB-RM118-40
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 7:19

Lab Sample Number: 211026039-041
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	2/24/2022	17:18	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTCL-DWB-RM119-42
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 7:23

Lab Sample Number: 211026039-043
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	31.1 **	µg/L	15	2/24/2022	17:54	JGW	2	2

nple Matrix: Drinking Water
Sample Location: JTCL-DW-RM119-43
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 7:24

Lab Sample Number: 211026039-044
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	2.30	µg/L	15	2/24/2022	17:59	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTCL-DWB-RM120-44
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 7:26

Lab Sample Number: 211026039-045
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
1-1st Draw	SM3113B	8.13	µg/L	15	2/24/2022	18:16	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTCL-DW-RM120-45
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 7:27

Lab Sample Number: 211026039-046
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	2/24/2022	18:21	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTCL-DWB-RM117-46
Sampled By: A. Marsico
Sample Date/Time: 2/11/2022 7:28

Lab Sample Number: 211026039-047
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	2/24/2022	18:27	JGW	2	1

Jefferson Township BOE

NJ Lab ID# 14013 (Dover)
NJ Lab ID# 13033 (Marlboro)

** Result does not meet NJDEP Limits.

NJDEP Limit for free and/or total chlorine does not apply to non-chlorinated samples.

Any method followed by an asterisk (*) was analyzed by the Agra-Marlboro laboratory.

All other methods, unless otherwise specified, were analyzed by the Agra-Dover laboratory.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan VanVeen

Susan VanVeen, Laboratory Manager

February 28, 2022

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

211026039

Customer Name: Jefferson Township BOE	Report to: Jefferson Township BOE	Agra Environmental Services
Location: 205 Cozy Lake Road	31 NJ-181	90 ½ West Blackwell Street
Address: 31 NJ-181	Lake Hopatcong, NJ, 07849	Dover, NJ 07801
Lake Hopatcong, NJ, 07849	jjahnke@jefftwp.org	Phone: (973) 989-0010
Customer Contact: Nick		Fax: (973) 989-0156
Phone: Work/Cell 973-663-5780 / 973-214-6997		

#	Asc./HCl Vials	pH:	
#	HCl Vials	pH:	
#	$Na_2S_2O_3$	Cl_2:	
* 42	HNO_3	pH:	
#	H_2SO_4	pH:	
#	NaOH	pH:	
# 12	unpreserved		
#	other		
#	other		

Matrix Abbreviations: DW - Drinking water GW - Ground Water RAW-GW - DW RAW GW WW/NPW - Wastewater SL - Sludge P - Pool L - Lake

Project: Cozy Lake Elementary

Collection PWSID#

for laboratory use only

Field Analysis

Sample ID	Location	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	pH / Temp	Cl_2 or PO_4
211026039-001	Field Blank	0601	2/11/22	X		DW	1	HNO3	Lead-1st Draw		
211026039-002	JTCL-POE-TAP	0603		X		DW	1	HNO3	Lead-1st Draw		
211026039-003	JTCL-WF-Hall-L-2	0605		X		DW	1	HNO3	Lead-1st Draw		
211026039-004	JTCL-WF-Hall-R-3	0606		X		DW	1	HNO3	Lead-1st Draw		
211026039-005	JTCL-FP-KC-3Baysink-4	0608		X		DW	1	HNO3	Lead-1st Draw		
211026039-006	JTCL-HW-KC-5	0609		X		DW	1	HNO3	Lead-1st Draw		
211026039-007	JTCL-NS-Sink-1-6	0613		X		DW	1	HNO3	Lead-1st Draw		
211026039-008	JTCL-NS-BR-Sink-2-7	0614		X		DW	1	HNO3	Lead-1st Draw		
211026039-009	JTCL-DWB-RM107-8	0619		X		DW	1	HNO3	Lead-1st Draw		
211026039-010	JTCL-DW-RM107-9	0620		X		DW	1	HNO3	Lead-1st Draw		

Sampled By (name/company): Anthony Marsico/Agra

Are these samples for compliance? (circle one): Yes or No

NJDEP Laboratory Certification (Dover, NJ) #14013

NJDEP Laboratory Certification (Marlboro, NJ) #13033

Indicate laboratory location where analysis request was performed

Cooler Temperature Upon Receipt at lab: N/A

Reporting Requirements (Check Box): Standard NJ Reduced Other (Specify)

Comments: * preserved w/ HNO3 @ 1300

Sample Custody Exchanges (Please use full legal signature)

Relinquished By:	Date:	Time:	Received By:	Date:	Time:
[signature]	2/11/22	1244	[signature]	2/11/22	1250
Relinquished By:	Date:	Time:	Received By:	Date:	Time:
Relinquished By:	Date:	Time:	Received By:	Date:	Time:
Relinquished By:	Date:	Time:	Received By:	Date:	Time:

Date Faxed _____

Invoice Number _____

Is sample known to be hazardous? (circle one) Yes or No

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

211026039

Customer Name:	Jefferson Township BOE	Report to: Jefferson Township BOE	Agra Environmental Services
Location:	205 Cozy Lake Road	31 NJ-181	90 ½ West Blackwell Street
Address:	31 NJ-181	Lake Hopatcong, NJ, 07849	Dover, NJ 07801
	Lake Hopatcong, NJ, 07849	jjahnke@jefftwp.org	Phone: (973) 989-0010
Customer Contact:	Nick		Fax: (973) 989-0156
Phone: Work/Cell	973-663-5780 / 973-214-6997		

#	Asc./HCl Vials	pH:
#	HCl Vials	pH:
#	$Na_2S_2O_3$	Cl_2:
#	HNO_3	pH:
#	H_2SO_4	pH:
#	NaOH	pH:
# ✓	unpreserved	
#	other	
#	other	

Matrix Abbreviations: DW - Drinking water GW - Ground Water RAW-GW - DW RAW GW WW/NPW - Wastewater SL - Sludge P - Pool L - Lake

Project: Cozy Lake Elementary

for laboratory use only

Sample ID	Location	Collection Date	Collection Time (AM)	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	Field Analysis pH / Temp	Field Analysis Cl_2 or PO_4
211026039-011	JTCL-DWB-RM108-10 Drinking	0623	2/11/22	X		DW	1	HNO3	Lead-1st Draw *Slow Drip*		
211026039-012	JTCL-DW-RM108-11	0624		X		DW	1	HNO3	Lead-1st Draw		
211026039-013	JTCL-WF-Hall-Boys RM-L-12	0626		X		DW	1	HNO3	Lead-1st Draw		
211026039-014	JTCL-WF-Hall-Girls RM-R-13	0627		X		DW	1	HNO3	Lead-1st Draw		
211026039-015	JTCL-DWB-RM109-14	0633		X		DW	1	HNO3	Lead-1st Draw		
211026039-016	JTCL-DW-RM109-15	0634		X		DW	1	HNO3	Lead-1st Draw		
211026039-017	JTCL-DWB-RM110-16	0635		X		DW	1	HNO3	Lead-1st Draw		
211026039-018	JTCL-DW-RM110-17	0636		X		DW	1	HNO3	Lead-1st Draw		
211026039-019	JTCL-DWB-RM101-18	0639		X		DW	1	HNO3	Lead-1st Draw		
211026039-020	JTCL-DW-RM101-19	0640		X		DW	1	HNO3	Lead-1st Draw		

Sampled By (name/company): Anthony Maurro/Agra

Are these samples for compliance? (circle one): Yes or No

NJDEP Laboratory Certification (Dover, NJ) #14013

NJDEP Laboratory Certification (Marlboro, NJ) #13033

Indicate laboratory location where analysis request was performed

Cooler Temperature Upon Receipt at lab: N/A

Reporting Requirements (Check Box): Standard NJ Reduced Other (Specify)

Comments: *Em 102 DWB Drinking

Sample Custody Exchanges (Please use full legal signature)

Relinquished By:	Date:	Time:	Received By:	Date:	Time:
[signature]	2/11/22	1244	[signature]	2/11/22	1250

Date Faxed _____

Invoice Number _____

Is sample known to be hazardous? (circle one) Yes or No

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

211026039

Customer Name:	Jefferson Township BOE	Report to: Jefferson Township BOE	Agra Environmental Services
Location:	205 Cozy Lake Road	31 NJ-181	90 ½ West Blackwell Street
Address:	31 NJ-181	Lake Hopatcong, NJ, 07849	Dover, NJ 07801
	Lake Hopatcong, NJ, 07849	jjahnke@jefftwp.org	Phone: (973) 989-0010
Customer Contact:	Nick		Fax: (973) 989-0156
Phone: Work/Cell	973-663-5780 / 973-214-6997		

#	Asc./HCl Vials	pH:	
#	HCl Vials	pH:	
#	$Na_2S_2O_3$	Cl_2:	
#	HNO_3	pH:	
#	H_2SO_4	pH:	
#	NaOH	pH:	
# 16	unpreserved		
#	other		
#	other		

Matrix Abbreviations: DW - Drinking water GW - Ground Water RAW-GW - DW RAW GW WW/NPW - Wastewater SL - Sludge P - Pool L - Lake

Project: Cozy Lake Elementary

for laboratory use only

Sample ID	Location	Collection Date	Collection Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	Field Analysis pH / Temp	Field Analysis Cl_2 or PO_4
211026039-021	JTCL-DWB-RM102-20	2/11/22	0643	X		DW	1	HNO3	Lead-1st Draw		
211026039-022	JTCL-DW-RM102-21		~~0644~~	X		DW	1	HNO3	Lead-1st Draw	No Sample	
211026039-023	JTCL-DWB-RM111-22		0647	X		DW	1	HNO3	Lead-1st Draw		
211026039-024	JTCL-DW-RM111-23		0649	X		DW	1	HNO3	Lead-1st Draw		
211026039-025	JTCL-DWB-RM112-24		0652	X		DW	1	HNO3	Lead-1st Draw		
211026039-026	JTCL-DW-RM112-25			X		DW	1	HNO3	Lead-1st Draw	No Sample	
211026039-027	JTCL-DWB-RM103-26		0653	X		DW	1	HNO3	Lead-1st Draw		
211026039-028	JTCL-DW-RM103-27		0654	X		DW	1	HNO3	Lead-1st Draw		
211026039-029	JTCL-DWB-RM104-28		0657	X		DW	1	HNO3	Lead-1st Draw		
211026039-030	JTCL-DW-RM104-29			X		DW	1	HNO3	Lead-1st Draw	No Sample	

Sampled By (name/company): Anthony Mass / Agra

Are these samples for compliance? (circle one): Yes or No

NJDEP Laboratory Certification (Dover, NJ) #14013

NJDEP Laboratory Certification (Marlboro, NJ) #13033

Indicate laboratory location where analysis request was performed

Cooler Temperature Upon Receipt at lab: N/A

Reporting Requirements (Check Box): Standard NJ Reduced Other (Specify)

Sample Custody Exchanges (Please use full legal signature)

Relinquished By:	Date:	Time:	Received By:	Date:	Time:
[signature]	2/11/22	1344	[signature]	2/11/22	1450
Relinquished By:	Date:	Time:	Received By:	Date:	Time:
Relinquished By:	Date:	Time:	Received By:	Date:	Time:
Relinquished By:	Date:	Time:	Received By:	Date:	Time:

Comments: Pb102 Do not analyze
Pb112 Do not analyze
Pb104 Do not analyze

Date Faxed _____

Invoice Number _____

Is sample known to be hazardous? (circle one) Yes or No

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

211026039

Customer Name: Jefferson Township BOE	Report to: Jefferson Township BOE	Agra Environmental Services
Location: 205 Cozy Lake Road	31 NJ-181	90 ½ West Blackwell Street
Address: 31 NJ-181	Lake Hopatcong, NJ, 07849	Dover, NJ 07801
Lake Hopatcong, NJ, 07849	jjahnke@jefftwp.org	Phone: (973) 989-0010
Customer Contact: Nick		Fax: (973) 989-0156
Phone: Work/Cell 973-663-5780 / 973-214-6997		

#	Asc./HCl Vials	pH:	
#	HCl Vials	pH:	
#	$Na_2S_2O_3$	Cl_2:	
#	HNO_3	pH:	
#	H_2SO_4	pH:	
#	NaOH	pH:	
# 16	unpreserved		
#	other		
#	other		

Matrix Abbreviations: DW - Drinking water GW - Ground Water RAW-GW - DW RAW GW WW/NPW - Wastewater SL - Sludge P - Pool L - Lake

Project: Cozy Lake Elementary Collection PWSID# for laboratory use only Field Analysis

Sample ID	Location	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	pH / Temp	Cl_2 or PO_4
211026039-031	JTCL-DW-RMB113-30	2/11/22	0700	X		DW	1	HNO3	Lead-1st Draw		
211026039-032	JTCL-DW-RM113-31		0701	X		DW	1	HNO3	Lead-1st Draw		
211026039-033	JTCL-DWB-RM114-32		0704	X		DW	1	HNO3	Lead-1st Draw		
211026039-034	JTCL-DW-RM114-33		0705	X		DW	1	HNO3	Lead-1st Draw		
211026039-035	JTCL-DWB-RM105-34		0709	X		DW	1	HNO3	Lead-1st Draw		
211026039-036	JTCL-DW-RM105-35		0710	X		DW	1	HNO3	Lead-1st Draw		
211026039-037	JTCL-DWB-RM115-36		0712	X		DW	1	HNO3	Lead-1st Draw		
211026039-038	JTCL-DW-RM115-37		0713	X		DW	1	HNO3	Lead-1st Draw		
211026039-039	JTCL-DWB-RM116-38		0718	X		DW	1	HNO3	Lead-1st Draw		
211026039-040	JTCL-DW-RM116-39		~~0719~~	X		DW	1	HNO3	Lead-1st Draw		

Sampled By (name/company): Anthony Marsico/AGA

Are these samples for compliance? (circle one): Yes or No

Indicate laboratory location where analysis request was performed

NJDEP Laboratory Certification (Dover, NJ) #14013

NJDEP Laboratory Certification (Marlboro, NJ) #13033

Cooler Temperature Upon Receipt at lab: NA

Reporting Requirements (Check Box): Standard NJ Reduced Other (Specify)

Sample Custody Exchanges (Please use full legal signature)

Relinquished By:	Date:	Time:	Received By:	Date:	Time:
[signature]	2/11/22	1614	[signature]	2/11/22	1650
Relinquished By:	Date:	Time:	Received By:	Date:	Time:
Relinquished By:	Date:	Time:	Received By:	Date:	Time:
Relinquished By:	Date:	Time:	Received By:	Date:	Time:

Comments: Rm 114 DW no Pressure
Rm 115 DW [illegible]

Date Faxed _____

Invoice Number _____

Is sample known to be hazardous? (circle one) Yes or No

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

211026039

Customer Name: Jefferson Township BOE
Location: 205 Cozy Lake Road
Address: 31 NJ-181
Lake Hopatcong, NJ, 07849
Customer Contact: Nick
Phone: Work/Cell 973-663-5780 / 973-214-6997

Report to: Jefferson Township BOE
31 NJ-181
Lake Hopatcong, NJ, 07849
jjahnke@jefftwp.org

Agra Environmental Services
90 ½ West Blackwell Street
Dover, NJ 07801
Phone: (973) 989-0010
Fax: (973) 989-0156

#	Asc./HCl Vials	pH:
#	HCl Vials	pH:
#	$Na_2S_2O_3$	Cl_2:
#	HNO_3	pH:
#	H_2SO_4	pH:
#	NaOH	pH:
# 16	unpreserved	
#	other	
#	other	

Matrix Abbreviations: DW - Drinking water GW - Ground Water RAW-GW - DW RAW GW WW/NPW - Wastewater SL - Sludge P - Pool L - Lake

Project: Cozy Lake Elementary

Collection PWSID#

for laboratory use only

Field Analysis

Sample ID	Location	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	pH / Temp	Cl_2 or PO_4
211026039-041	JTCL-DWB-RM118-40		0719	X		DW	1	HNO3	Lead-1st Draw		
211026039-042	JTCL-DW-RM118-41			X		DW	1	HNO3	Lead-1st Draw No sample		
211026039-043	JTCL-DWB-RM119-42		0723	X		DW	1	HNO3	Lead-1st Draw		
211026039-044	JTCL-DW-RM119-43		0724	X		DW	1	HNO3	Lead-1st Draw		
211026039-045	JTCL-DWB-RM120-44		0726	X		DW	1	HNO3	Lead-1st Draw		
211026039-046	JTCL-DW-RM120-45		0727	X		DW	1	HNO3	Lead-1st Draw		
211026039-047	JTCL-DWB-RM117-46		0729	X		DW	1	HNO3	Lead-1st Draw		
211026039-048	JTCL-DW-RM117-47			X		DW	1	HNO3	Lead-1st Draw No sample		
211026039-049	JTCL-DW-RM115-48			X		DW	1	HNO3	Lead-1st Draw		
211026039-050	JTCL-DW-RM115-49			X		DW	1	HNO3	Lead-1st Draw		

Sampled By (name/company): Anthony Mendez/AGA

Are these samples for compliance? (circle one): Yes or No

NJDEP Laboratory Certification (Dover, NJ) #14013
NJDEP Laboratory Certification (Marlboro, NJ) #13033

Indicate laboratory location where analysis request was performed

Cooler Temperature Upon Receipt at lab: N/A

Reporting Requirements (Check Box): Standard NJ Reduced Other (Specify)

Sample Custody Exchanges (Please use full legal signature)

Relinquished By:	Date:	Time:	Received By:	Date:	Time:
[signature]	2/11/22	1244	[signature]	2/11/22	1450
Relinquished By:	Date:	Time:	Received By:	Date:	Time:
Relinquished By:	Date:	Time:	Received By:	Date:	Time:
Relinquished By:	Date:	Time:	Received By:	Date:	Time:

Comments:
Rm 118 Dr Did not [illegible]
Rm 119 [illegible]
Rm 7 [illegible] not work

Date Faxed _____
Invoice Number _____

Is sample known to be hazardous? (circle one) Yes or No