



**Environmental and Laboratory Services**  
90 ½ West Blackwell St., Dover, New Jersey 07801  
(973) 989-0010 P, (973) 989-0156 F

## Analytical Results

Date: June 26, 2017

Address: Jefferson Township High School  
1010 Weldon Road  
Oak Ridge, NJ 07438

Project: Jefferson Township High School

Sample description: Drinking Water / 1<sup>st</sup> Draw/ DWS5675-1  
Sample location: Field Blank  
Sampled by: J. MacDonald / S. Flyte / S. Berta  
Sample date: 06/10/17  
Time: 06:09  
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/16/17	18:13	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-2  
Sample location: JTHS-POE-1-Boiler Rm  
Sampled by: J. MacDonald / S. Flyte / S. Berta  
Sample date: 06/10/17  
Time: 06:14  
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	75.0 µg/L	15 µg/L	06/16/17	18:26	4	8.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-3  
Sample location: JTHS-DW-2  
Sampled by: J. MacDonald / S. Flyte / S. Berta  
Sample date: 06/10/17  
Time: 06:20  
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	14.9 µg/L	15 µg/L	06/16/17	18:32	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-4  
Sample location: JTHS-KC-4  
Sampled by: J. MacDonald / S. Flyte / S. Berta  
Sample date: 06/10/17  
Time: 06:25  
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.02 µg/L	15 µg/L	06/16/17	18:38	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-5  
 Sample location: JTHS-KC-5  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 06:25  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	8.14 µg/L	15 µg/L	06/16/17	18:56	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-6  
 Sample location: JTHS-KC-6  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 06:25  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	36.0 µg/L	15 µg/L	06/16/17	19:06	2	4.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-7  
 Sample location: JTHS-KC-7  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 06:26  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.22 µg/L	15 µg/L	06/16/17	19:20	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-8  
 Sample location: JTHS-KC-8  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 06:27  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/16/17	19:45	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-9  
 Sample location: JTHS-FP-9  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 06:29  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/16/17	19:52	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-10  
 Sample location: JTHS-KC-10  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 06:30  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/16/17	19:58	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-11  
 Sample location: JTHS-KC-11  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 06:31  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/16/17	20:05	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-12  
 Sample location: JTHS-KC-11A  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 06:42  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/16/17	20:11	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-13  
 Sample location: JTHS-DW-16  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 07:06  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	6.84 µg/L	15 µg/L	06/16/17	20:24	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-14  
 Sample location: JTHS-DW-17  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 07:08  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	6.13 µg/L	15 µg/L	06/16/17	20:31	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-15  
 Sample location: JTHS-NS-18  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 07:13  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	5.21 µg/L	15 µg/L	06/16/17	20:37	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-16  
 Sample location: JTHS-CT-19-01  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 07:15  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.98 µg/L	15 µg/L	06/16/17	20:43	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-17  
 Sample location: JTHS-CT-20-02  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 07:15  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	46.8 µg/L	15 µg/L	06/16/17	20:56	4	8.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-18  
 Sample location: JTHS-CT-21-03  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 07:16  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/16/17	21:02	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-19  
 Sample location: JTHS-CT-22-04  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 07:17  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/16/17	21:08	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-20  
 Sample location: JTHS-CT-23-05  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 07:18  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/16/17	21:15	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-21  
 Sample location: JTHS-CT-24-06  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 07:18  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/16/17	21:33	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-22  
 Sample location: JTHS-CT-25-07  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 07:19  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/16/17	21:39	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-23  
 Sample location: JTHS-DW-26-01  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 07:21  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/16/17	21:46	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-24  
 Sample location: JTHS-DW-27-02  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 07:21  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/16/17	21:52	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-25  
 Sample location: JTHS-DW-27A-01  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 07:24  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/16/17	21:58	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-26  
 Sample location: JTHS-DW-27B-02  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 07:24  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/16/17	22:09	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-27  
 Sample location: JTHS-DWB-28-01  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 07:26  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	4.29 µg/L	15 µg/L	06/22/17	18:46	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-28  
 Sample location: JTHS-DW-29-02  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 07:27  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.08 µg/L	15 µg/L	06/16/17	22:33	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-29  
 Sample location: JTHS-DWB-30-03  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 07:27  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.65 µg/L	15 µg/L	06/16/17	22:39	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-30  
 Sample location: JTHS-DW-31-04  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 07:28  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.89 µg/L	15 µg/L	06/16/17	22:45	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-31  
 Sample location: JTHS-DW-32-01  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 07:33  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.45 µg/L	15 µg/L	06/16/17	22:57	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-32  
 Sample location: JTHS-DW-33-02  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 07:34  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	4.11 µg/L	15 µg/L	06/16/17	23:03	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-33  
 Sample location: JTHS-TL-34  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 07:38  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/16/17	23:09	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-34  
 Sample location: JTHS-DW-35  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 07:39  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.73 µg/L	15 µg/L	06/16/17	23:15	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-35  
 Sample location: JTHS-DW-36  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 07:39  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.80 µg/L	15 µg/L	06/16/17	23:21	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-36  
 Sample location: JTHS-DW-37  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 07:42  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/16/17	23:27	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-37  
 Sample location: JTHS-DW-38  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 07:42  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/16/17	23:33	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-38  
 Sample location: JTHS-DW-39-02  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 07:46  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/16/17	23:39	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-39  
 Sample location: JTHS-DW-40-01  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 07:54  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	5.59 µg/L	15 µg/L	06/16/17	23:45	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-40  
 Sample location: JTHS-DW-42  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 08:00  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/16/17	23:51	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-41  
 Sample location: JTHS-DW-43  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 08:01  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.33 µg/L	15 µg/L	06/17/17	00:08	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-42  
 Sample location: JTHS-TL-44  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 08:03  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.76 µg/L	15 µg/L	06/17/17	00:15	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-43  
 Sample location: JTHS-DW-45-01  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 08:08  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	4.05 µg/L	15 µg/L	06/17/17	00:21	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-44  
 Sample location: JTHS-FC-17A  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 07:09  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/17/17	00:27	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-45  
 Sample location: JTHS-FC-38A  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 07:43  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/17/17	00:33	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-46  
 Sample location: JTHS-DW-40-02  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 07:55  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.35 µg/L	15 µg/L	06/17/17	00:44	1	2.00 µg/L



Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-47  
 Sample location: JTHS-DW-Guidance-46  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 08:06  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/17/17	01:08	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-48  
 Sample location: JTHS-DW-BL-47  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 08:13  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/17/17	01:14	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-49  
 Sample location: JTHS-DW-GL-01-48  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 08:19  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/17/17	01:20	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-50  
 Sample location: JTHS-DW-GL-02-49  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 08:19  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/17/17	01:32	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-51  
 Sample location: JTHS-KC-IM-50  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 08:19  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/17/17	01:39	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5675-52  
 Sample location: JTHS-Trainer-IM-51  
 Sampled by: J. MacDonald / S. Flyte / S. Berta  
 Sample date: 06/10/17  
 Time: 08:21  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/17/17	01:45	1	2.00 µg/L

µg/L = micrograms per liter

**Field Notes:**

**Automatic flushing toilet system in operation at time of sampling**

**DWS5675-13: Very Low pressure**

**DWS5675-14: Low pressure**

**DWS5675-27: Extremely Low pressure**

**DWS5675-41: Low pressure**

All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Laurette Yang (For SV)  
Susan VanVeen, Lab Manager  
NJ Laboratory Certification ID # 14013

July 8, 2017  
Date

# CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Toilets Flushing

Customer Name: Jefferson Twp High School	report to:	Agra Environmental Services
Address: 1010 Weldon Rd		90½ West Blackwell Street
Oak Ridge NJ 07438		Dover, NJ 07801
County/Municipality:		Phone: (973) 989-0010
Phone: 973-697-3535		Fax: (973) 989-0156
Work:		

#	Asc./HCl Vials	pH:
#	HCl Vials	pH:
#	Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub>	Cl <sub>2</sub> :
#	HNO <sub>3</sub> <i>pgm</i>	pH: <i>2</i>
#	H <sub>2</sub> SO <sub>4</sub>	pH:
#	NaOH	pH:
#	unpreserved	
#	other	
#	other	

Matrix Abbreviations: D - Drinking Water G- Groundwater W- Wastewater S- Soil SL- Sludge P-Pool L-Lake

Project: Collection PWSID# NJ for laboratory use only

Field ID	Lab ID:	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED
DWS5675									
Field Blank	-1	6/10/17	0609	X			1	MNO <sub>3</sub>	1st Draw Pb 22.00 ug/L 6/16/17 1813 BM
JTHS-POE-1 - Boiler Rm	-2		0619				1		1st Draw Pb 75.0 1826 1:4
JTHS-DW-2	-3		0620				1		1st Draw Pb 14.9 1832
JTHS-KC-3									1st Draw Pb No water
JTHS-KC-4	-4		0625				1		1st Draw Pb 3.02 ug/L 6/16/17 1838 BM
JTHS-KC-5	-5		0625				1		1st Draw Pb 8.14 1856
JTHS-KC-6	-6		0625				1		1st Draw Pb 36.0 1906 1:2
JTHS-KC-7	-7		0626				1		1st Draw Pb 3.22 1920
JTHS-KC-8	-8		0627				1		1st Draw Pb 42.00 1945
JTHS-FP-9	-9		0629				1		1st Draw Pb 22.00 1952

Sampled By (name/company): <i>Sm/SE/SB</i>	State Forms Needed (circle one): Yes or No		indicate laboratory location where analysis requested was performed
	NJDEP Laboratory Certification (Dover, NJ) #14013		
	NJDEP Laboratory Certification (Marlboro, NJ) #13033		

Reporting Requirements (Check Box):	Standard	NJ Reduced	Other (Specify)	Cooler Temperature Upon Receipt at lab:
-------------------------------------	----------	------------	-----------------	---

Sample Custody Exchanges (Please use full legal signature)						Scanned	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Toilets Flushing	
<i>Sherry Ayle</i>	6/12/17	1000	<i>[Signature]</i>	6/12/17	1104		
Relinquished By:	Date:	Time:	Received By:	Date:	Time:		
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Date Faxed	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Invoice Number	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Is sample known to be hazardous? (circle one) Yes or No	



# CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Customer Name: Jefferson Twp High School

Address: 1010 Weldon Rd  
Oak Ridge NJ 07438

County/Municipality:

Phone: 973-697-3535

Work:

Report to:

Agra Environmental Services  
90 1/2 West Blackwell Street  
Dover, NJ 07801  
Phone: (973) 989-0010  
Fax: (973) 989-0156



Matrix Abbreviations: D - Drinking Water G - Groundwater W - Wastewater S - Soil SL - Sludge P - Pool L - Lake

Project:

Collection

PWSID# NJ

for laboratory use only

Page 1 of 1  
Field Analysis

Field ID: DM 55675

Lab ID:

Date

Time

Grab

Comp

Matrix

# of Bottles

Preservative

ANALYSIS REQUESTED

JTHS-KC-10

-16 6/10/17

0630

X

1

None

1st Draw Pb 2.00ug/L 6/16/17 1458 PM

JTHS-KC-11

-17

0631

1st Draw Pb 2.00ug/L 2005

JTHS-KC-11A

-17

0642

1st Draw Pb 2.00ug/L 2011

JTHS-KC-12

1st Draw Pb

JTHS-KC-13

1st Draw Pb

JTHS-KC-14

1st Draw Pb

JTHS-KC-15

-18

0706

1st Draw Pb 1054 low pressure 6/8/17 6/16

JTHS-DW-16

-18

0709

1st Draw Pb 6.13

JTHS-DW-17

-15

0713

1st Draw Pb 5.31

JTHS-NS-18

Sampled By (name/company): SM 1/24/18

State Forms Needed (circle one): Yes or No

NUDEP Laboratory Certification (Dover, NJ) #14013

NUDEP Laboratory Certification (Marlboro, NJ) #13033

Indicate laboratory location where analysis requested was performed

Cooler Temperature Upon Receipt at lab:

Reporting Requirements (Check Box):

Standard

NJ

Reduced

Other (Specify)

Sample Custody Exchanges (Please use full legal signature)

Relinquished By:

Date:

Time:

Received By:

Date:

Time:

Scanned

Relinquished By:

Date:

Time:

Received By:

Date:

Time:

Relinquished By:

Date:

Time:

Received By:

Date:


Time:

Date Faxed

Invoice Number

Is sample known to be hazardous? (circle one)  
Yes or No



# CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Customer Name: Jefferson Twp High School	report to:	Agra Environmental Services	
Address: 1010 Weldon Rd		90½ West Blackwell Street	
Oak Ridge NJ 07438		Dover, NJ 07801	
County/Municipality:		Phone: (973) 989-0010	
Phone: 973-697-3535		Fax: (973) 989-0156	
Work:			

Matrix Abbreviations: D - Drinking Water G- Groundwater W- Wastewater S- Soil SL- Sludge P-Pool L-Lake Page 1 of 1

Project:	Collection	PWSID# NJ						for laboratory use only	Field Analysis
DW55675	Lab ID:		Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	
Field ID	Date	Time							
JTHS-CT-19-01	-16	6/10/17	0715	X			H103	1st Draw Pb 3.98 ug/L 6/16/17 2043	BM
JTHS-CT-20-02	-17		0715					1st Draw Pb 46.87 2056	1:4
JTHS-CT-21-03	-18		0716					1st Draw Pb 2.00 2102	
JTHS-CT-22-04	-19		0717					1st Draw Pb 2.00 2108	
JTHS-CT-23-05	-20		0718					1st Draw Pb 2.00 2115	
JTHS-CT-24-06	-21		0718					1st Draw Pb 2.00 2133	
JTHS-CT-25-07	-22		0719					1st Draw Pb 2.00 2139	
JTHS-DW-26-01	-23		0721					1st Draw Pb 2.00 2146	
JTHS-DW-27-02	-24		0721					1st Draw Pb 2.00 2152	
JTHS-DW-27A-01	-25		0724					1st Draw Pb 2.00 2158	

Sampled By (name/company): Jm / SF / SB	State Forms Needed (circle one): Yes or No		indicate laboratory location where analysis requested was performed	
	NJDEP Laboratory Certification (Dover, NJ) #14013			
	NJDEP Laboratory Certification (Marlboro, NJ) #13033			
Reporting Requirements (Check Box):	Standard	NJ Reduced	Other (Specify)	Cooler Temperature Upon Receipt at lab:

Sample Custody Exchanges (Please use full legal signature)						Scanned _____
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
	6/12/17	1:00		6/12/17	1:04	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Date Faxed _____
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Invoice Number _____
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Is sample known to be hazardous? (circle one) Yes or No



# CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Customer Name: Jefferson Twp High School	report to:	Agra Environmental Services
Address: 1010 Weldon Rd		90½ West Blackwell Street
Oak Ridge NJ 07438		Dover, NJ 07801
County/Municipality:		Phone: (973) 989-0010
Phone: 973-697-3535		Fax: (973) 989-0156
Work:		



Matrix Abbreviations: D - Drinking Water G- Groundwater W- Wastewater S- Soil SL- Sludge P-Pool L-Lake Page 1 of 1

Project: Collection PWSID# NJ for laboratory use only Field Analysis

Field ID	Lab ID:	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED		
DW55675											
JTHS-DW-27B-02	-26	6/10/17	0724	X			1	HNO3	1st Draw Pb 2.00 ug/L 6/16/17 2209	BM	
JTHS-DW-28-01	DWB -27		0746						1st Draw Pb extremely low pressure	Digest 4.29 ug/L 6/22/17 1846 BM	
JTHS-DW-29-02	-28		0727						1st Draw Pb 2.08 ug/L 6/16/17 2233	BM	
JTHS-DW-30-03	DWB -29		0727						1st Draw Pb 2.65	2239	
JTHS-DW-31-04	-30		0728						1st Draw Pb 2.89	2245	
JTHS-DW-32-01	-31		0733						1st Draw Pb 3.45	2257	
JTHS-DW-33-02	-32		0734						1st Draw Pb 4.11	2303	
JTHS-TL-34	-33		0738						1st Draw Pb 2.00	2309	
JTHS-DW-35	-34		0739						1st Draw Pb 3.73	2315	
JTHS-DW-36	-35		0739						1st Draw Pb 2.80	2321	

Sampled By (name/company): Jm/SE/SB	State Forms Needed (circle one): Yes or No		indicate laboratory location where analysis requested was performed	
	NJDEP Laboratory Certification (Dover, NJ) #14013			
	NJDEP Laboratory Certification (Marlboro, NJ) #13033			

Reporting Requirements (Check Box):	Standard	NJ Reduced	Other (Specify)	Cooler Temperature Upon Receipt at lab:
-------------------------------------	----------	------------	-----------------	---

Sample Custody Exchanges (Please use full legal signature) Scanned \_\_\_\_\_

Relinquished By: <i>Cherry Byle</i>	Date: 6/15/17	Time: 1000	Received By: <i>[Signature]</i>	Date: 6/17/17	Time: 1104	Date Faxed _____ Invoice Number _____ Is sample known to be hazardous? (circle one) Yes or No
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	

# CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Customer Name: Jefferson Twp High School

report to:

Agra Environmental Services

Address: 1010 Weldon Rd

90½ West Blackwell Street

Oak Ridge NJ 07438

Dover, NJ 07801

County/Municipality:

Phone: (973) 989-0010

Phone: 973-697-3535

Fax: (973) 989-0156

Work:



Matrix Abbreviations: D - Drinking Water G- Groundwater W- Wastewater S- Soil SL- Sludge P-Pool L-Lake Page 1 of 1

Project: Collection PWSID# NJ for laboratory use only Field Analysis

Field ID	Lab ID:	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED		
JTHS-DW-37	-36	6/10/17	0742	X			1	11/12	1st Draw Pb 2.00 ug/L 6/16/17 2337	BM	
JTHS-DW-38	-37	2	0742				1		1st Draw Pb 2.00 1 1 2333	1	
JTHS-DW-39-01	-38								1st Draw Pb		
JTHS-DW-39-02	-38		0746						1st Draw Pb 2.00 ug/L 6/16/17 2339	BM	
JTHS-DW-40	-01		0754						1st Draw Pb 5.59 1 1 2345	1	
JTHS-DW-41									1st Draw Pb		
JTHS-DW-42	-42		0800						1st Draw Pb 2.00 ug/L 6/16/17 2351	BM	
JTHS-DW-43	-43		0801						1st Draw Pb low pressure 2.33 ug/L 6/17/17 0008	BM	
JTHS-TL-44	-44		0803						1st Draw Pb 3.76 ug/L 6/17/17 0015	BM	
JTHS-DW-45-01	-45		0803						1st Draw Pb 4.05 1 0021	1	

Sampled By (name/company): State Forms Needed (circle one): Yes or No indicate laboratory location where analysis requested was performed

Reporting Requirements (Check Box): Standard NJ Reduced Other (Specify) Cooler Temperature Upon Receipt at lab:

Sample Custody Exchanges (Please use full legal signature) Scanned

Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Date Faxed Invoice Number Is sample known to be hazardous? (circle one) Yes or No
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	



# CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Customer Name: <u>Jesserson Twp High School</u>	report to:	Agra Environmental Services
Address: <u>1010 Walton Rd</u>		901 1/2 West Blackwell Street
County/Municipality: <u>Oak Ridge NJ 07438</u>		Dover, NJ 07801
Phone: <u>973-697-3535</u>		Phone: (973) 989-0010
Work:		Fax: (973) 989-0156

**Agra**

Matrix Abbreviations: D - Drinking Water G - Groundwater W - Wastewater S - Soil SL - Sludge P - Pool L - Lake Page \_\_\_\_ of \_\_\_\_

Project:		Collection		PWSID# NJ		for laboratory use only		Field Analysis	
Field ID	Lab ID:	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED
DW55675									
STHS-FC-17A	-45	01/10/17	0709	X			1	4/003	1st Draw Pb 22.00 ug/L
STHS-FC-38A	-48	07/13							1st Draw Pb 22.00
STHS-DW-4000	-46	07/55							1st Draw Pb 2.35
STHS-DW-Guidance-46	-47	0306							1st Draw Pb 22.00
STHS-DW-86-47	-48	0813							1st Draw Pb 22.00
STHS-DW-GL-01-48	-49	0819							1st Draw Pb 22.00
STHS-DW-GL-02-49	-10	0819							1st Draw Pb 22.00
STHS-KC-EM-50	-51	0819							1st Draw Pb 22.00
STHS-TR-05-EM-51	-52	0826							1st Draw Pb 22.00

Sampled By (name/company): <u>SM/ST/SD</u>	State Forms Needed (circle one): Yes or No		indicate laboratory location where analysis requested was performed	
	NJDEP Laboratory Certification (Dover, NJ) #14013			
	NJDEP Laboratory Certification (Marlboro, NJ) #13033			
Reporting Requirements (Check Box):	Standard	NJ Reduced	Other (Specify)	Cooler Temperature Upon Receipt at lab:

Sample Custody Exchanges (Please use full legal signature)						Scanned _____	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:		
<u>Sherry J. Jaffe</u>	<u>6/11/17</u>	<u>1000</u>	<u>[Signature]</u>	<u>6/11/17</u>	<u>1104</u>		
Relinquished By:	Date:	Time:	Received By:	Date:	Time:		
Relinquished By:	Date:	Time:	Received By:	Date:	Time:		
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Date Faxed _____	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Invoice Number _____	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Is sample known to be hazardous? (circle one) Yes or No	



**Attachment C – Drinking Water Outlet Inventory**

(Complete for each school)

Name of School: Jefferson Township High School Address: 1010 Weldon Road Oak Ridge, NJ 07438Grade Levels: 9 – 12 Year School Constructed: \_\_\_\_\_ Renovated/Additions: \_\_\_\_\_

Individual school project officer Name/Signature: \_\_\_\_\_ Date Completed: \_\_\_\_\_

# <sup>2</sup>	Type	Location	Code	Operational <sup>3</sup> (Y/N)	Signs of Corrosion <sup>4</sup> (Y/N)	Filter <sup>5</sup> (Y/N)	Brass Fittings, Faucets or valves? (Y/N)	Aerator/ Screen (Y/N)	Motion Activated (Y/N)	Chiller (Y/N)	Water Cooler		Comments
											Make	Model	
1	POE	Old Boiler Room	JTHS-POE-1	Y	N	N	Y	Y	N	N			
2	DW	F-Wing Hallway	JTHS-DW-2	Y	N	N	Y	Y	N	N			
3	KC	Old Cafeteria	JTHS-KC-3	Y	N	N	Y	Y	N	N			
4	KC	Old Kitchen	JTHS-KC-4	Y	N	N	Y	Y	N	N			
5	KC	Old Kitchen	JTHS-KC-5	Y	N	N	Y	Y	N	N			
6	KC	Old Kitchen	JTHS-KC-6	Y	N	N	Y	Y	N	N			
7	KC	Old Kitchen	JTHS-KC-7	Y	N	N	Y	Y	N	N			
8	KC	New Kitchen	JTHS-KC-8	Y	N	N	Y	Y	N	N			
9	FP	New Kitchen	JTHS-FP-9	Y	N	N	Y	Y	N	N			
10	KC	New Kitchen	JTHS-KC-10	Y	N	N	Y	Y	N	N			
11	KC	New Kitchen	JTHS-KC-11	Y	N	N	Y	Y	N	N			
11A	KC	Snack Shack	JTHS-KC-11A	Y	N	N	Y	Y	N	N			

<sup>2</sup> Number outlets starting at the closest outlet to the Point of Entry (POE).<sup>3</sup> Document if permanently or temporarily out of service on the Attachment B- Plumbing Profile.<sup>4</sup> Signs of corrosion detected, such as but not limited to frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry.<sup>5</sup> Document on Attachment D- Filter Inventory.

Jefferson Township School District Sampling Plan  
May 25, 2017

Version 1

12	KC	New Kitchen	JTHS-KC-12	Y	N	N	Y	Y	N	N			
13	KC	New Kitchen	JTHS-KC-13	Y	N	N	Y	Y	N	N			
14	KC	New Kitchen	JTHS-KC-14	Y	N	N	Y	Y	N	N			
15	KC	New Kitchen	JTHS-KC-15	Y	N	N	Y	Y	N	N			
16	DW	B-Wing	JTHS-DW-16	Y	N	N	Y	Y	N	N			
17	DW		JTHS-DW-17	Y	N	N	Y	Y	N	N			
18	NS	B-Wing Nurse	JTHS-NS-18	Y	N	N	Y	Y	N	N			
19	CT	Room B1	JTHS-CT-19-01	Y	N	N	Y	Y	N	N			
20	CT	Room B1	JTHS-CT-20-02	Y	N	N	Y	Y	N	N			
21	CT	Room B1	JTHS-CT-21-03	Y	N	N	Y	Y	N	N			
22	CT	Room B1	JTHS-CT-22-04	Y	N	N	Y	Y	N	N			
23	CT	Room B1	JTHS-CT-23-05	Y	N	N	Y	Y	N	N			
24	CT	Room B1	JTHS-CT-24-06	Y	N	N	Y	Y	N	N			
25	CT	Room B1	JTHS-CT-25-07	Y	N	N	Y	Y	N	N			
26	DW	GWING LEFT	JTHS-DW-26-01	Y	N	N	Y	Y	N	N			
27	DW	GWING RIGHT	JTHS-DW-27-02	Y	N	N	Y	Y	N	N			
27A	DW	ACROSS RM D9 LEFT	JTHS-DW-27A-01	Y	N	N	Y	Y	N	N			
27B	DW	ACROSS RM D9 RGT	JTHS-DW-27B-02	Y	N	N	Y	Y	N	N			
28	DW	ROOM 9	JTHS-DW-28-01	Y	N	N	Y	Y	N	N			
29	DW	ROOM 9	JTHS-DW-29-02	Y	N	N	Y	Y	N	N			
30	DW	ROOM 9	JTHS-DW-30-03	Y	N	N	Y	Y	N	N			
31	DW	ROOM 9	JTHS-DW-31-04	Y	N	N	Y	Y	N	N			
32	DW	DWING BY GIRLS RM	JTHS-DW-32-01	Y	N	N	Y	Y	N	N			
33	DW	DWING BY GIRLS RM	JTHS-DW-33-02	Y	N	N	Y	Y	N	N			
34	TL	ROOM E13	JTHS-TL-34	Y	N	N	Y	Y	N	N			
35	DW	EWING BOYS RM	JTHS-DW-35	Y	N	N	Y	Y	N	N			
36	DW	EWING GIRLS RM	JTHS-DW-36	Y	N	N	Y	Y	N	N			
37	DW	JWING BY GYM	JTHS-DW-37	Y	N	N	Y	Y	N	N			
38	DW	JWING BY GYM	JTHS-DW-38	Y	N	N	Y	Y	N	N			
39	DW	<del>TICKET-BOOTH</del>	<del>JTHS-DW-39-01</del>	Y	N	N	Y	Y	N	N			
39A	DW	CONSESSION	JTHS-DW-39-02	Y	N	N	Y	Y	N	N			
40	DW	CWING GIRLS	JTHS-DW-40-01	Y	N	N	Y	Y	N	N			
41	DW	C2 ROOM	JTHS-DW-41	Y	N	N	Y	Y	N	N			

Jefferson Township School District Sampling Plan  
May 25, 2017

Version 1

42	DW	MAIN OFFICE	JTHS-DW-42	Y	N	N	Y	Y	N	N		
43	DW	A3 FILE ROOM	JTHS-DW-43	Y	N	N	Y	Y	N	N		
44	TL	A11	JTHS-TL-44	Y	N	N	Y	Y	N	N		
45	DW	G218 G WING	JTHS-DW-45-01	Y	N	N	Y	Y	N	N		
45	DW	G218 G WING	JTHS-DW-45-02	Y	N	N	Y	Y	N	N		
46	TL	Guardhouse	JTHS-DW-45-02	Y	N	N	Y	Y	N	N		

Attachment C – Drinking Water Outlet Inventory  
(Complete for each school)