



Environmental and Laboratory Services

Dover Location:
 90 1/2 West Blackwell St., Dover, NJ 07801
 Phone: (973) 989-0010, Fax (973) 989-0156

Marlboro Location:
 8A Railroad Ave, Marlboro, NJ 07746
 Phone: (732) 308-3500, Fax (732) 308-3503

Date: February 01, 2022
 Client: Jefferson Township BOE
 Address: 31 NJ-181
 Lake Hopatcong, NJ 07849

Analytical Results

PWSID#:
 Project Location: 1000 Weldon Road, Oak Ridge

Sample Matrix:	Drinking Water	Lab Sample Number: 211027017-001
Sample Location:	Field Blank	Customer Sample Number:
Sampled By:	C. Anzolut	
Sample Date/Time:	1/18/2022 5:25	

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	<2.00	µg/L	15	1/27/2022	14:34	BM	2	1

Sample Matrix:	Drinking Water	Lab Sample Number: 211027017-002
Sample Location:	JTMS-POE-01	Customer Sample Number:
Sampled By:	C. Anzolut	
Sample Date/Time:	1/18/2022 5:26	

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	4.10	µg/L	15	1/27/2022	14:56	BM	2	1

Sample Matrix: Drinking Water Lab Sample Number: 211027017-003
 Sample Location: JTMS-DW-02-01 Customer Sample Number:
 Sampled By: C. Anzolut
 Sample Date/Time: 1/18/2022 5:30

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/27/2022	15:01	BM	2	1

Sample Matrix: Drinking Water Lab Sample Number: 211027017-004
 Sample Location: JTMS-DW-03-02 Customer Sample Number:
 Sampled By: C. Anzolut
 Sample Date/Time: 1/18/2022 5:30

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/27/2022	15:06	BM	2	1

Sample Matrix: Drinking Water Lab Sample Number: 211027017-006
 Sample Location: JTMS-TL-04 Customer Sample Number:
 Sampled By: C. Anzolut
 Sample Date/Time: 1/18/2022 5:33

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	4.07	µg/L	15	1/27/2022	15:12	BM	2	1

Sample Matrix: Drinking Water Lab Sample Number: 211027017-007
 Sample Location: JTMS-CT-05-01 Customer Sample Number:
 Sampled By: C. Anzolut
 Sample Date/Time: 1/18/2022 5:35

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	6.56	µg/L	15	1/27/2022	15:17	BM	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 211027017-008							
Sample Location: JTMS-CT-06-02		Customer Sample Number:							
Sampled By: C. Anzolut									
Sample Date/Time: 1/18/2022 5:35									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	5.32	µg/L	15	1/27/2022	15:23	BM	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 211027017-009							
Sample Location: JTMS-CT-07-03		Customer Sample Number:							
Sampled By: C. Anzolut									
Sample Date/Time: 1/18/2022 5:36									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/27/2022	15:28	BM	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 211027017-010							
Sample Location: JTMS-CT-08-04		Customer Sample Number:							
Sampled By: C. Anzolut									
Sample Date/Time: 1/18/2022 5:36									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/27/2022	15:34	BM	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 211027017-011							
Sample Location: JTMS-CT-09-05		Customer Sample Number:							
Sampled By: C. Anzolut									
Sample Date/Time: 1/18/2022 5:37									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/27/2022	15:56	BM	2	1

Sample Matrix:	Drinking Water	Lab Sample Number: 211027017-012
Sample Location:	JTMS-CT-10-06	Customer Sample Number:
Sampled By:	C. Anzolut	
Sample Date/Time:	1/18/2022 5:37	

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	24.6 **	µg/L	15	1/27/2022	16:04	BM	4	2

Sample Matrix:	Drinking Water	Lab Sample Number: 211027017-013
Sample Location:	JTMS-CT-11-07	Customer Sample Number:
Sampled By:	C. Anzolut	
Sample Date/Time:	1/18/2022 5:38	

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	47.3 **	µg/L	15	1/27/2022	16:15	BM	8	4

Sample Matrix:	Drinking Water	Lab Sample Number: 211027017-014
Sample Location:	JTMS-DW-12-01	Customer Sample Number:
Sampled By:	C. Anzolut	
Sample Date/Time:	1/18/2022 5:50	

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	3.35	µg/L	15	1/27/2022	16:20	BM	2	1

Sample Matrix:	Drinking Water	Lab Sample Number: 211027017-015
Sample Location:	JTMS-DW-13-02	Customer Sample Number:
Sampled By:	C. Anzolut	
Sample Date/Time:	1/18/2022 5:50	

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	4.15	µg/L	15	1/27/2022	16:26	BM	2	1

Sample Matrix: Drinking Water Lab Sample Number: 211027017-016
 Sample Location: JTMS-DW-14-03 Customer Sample Number:
 Sampled By: C. Anzolut
 Sample Date/Time: 1/18/2022 5:50

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	4.32	µg/L	15	1/27/2022	16:31	BM	2	1

Sample Matrix: Drinking Water Lab Sample Number: 211027017-018
 Sample Location: JTMS-DW-16 Customer Sample Number:
 Sampled By: C. Anzolut
 Sample Date/Time: 1/18/2022 6:12

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
1st Draw	SM3113B	2.50	µg/L	15	1/27/2022	16:37	BM	2	1

Sample Matrix: Drinking Water Lab Sample Number: 211027017-019
 Sample Location: JTMS-DW-17-01 Customer Sample Number:
 Sampled By: C. Anzolut
 Sample Date/Time: 1/18/2022 6:22

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	7.25	µg/L	15	1/27/2022	16:59	BM	2	1

Sample Matrix: Drinking Water Lab Sample Number: 211027017-020
 Sample Location: JTMS-DW-18-02 Customer Sample Number:
 Sampled By: C. Anzolut
 Sample Date/Time: 1/18/2022 6:22

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	7.87	µg/L	15	1/27/2022	17:05	BM	2	1

Sample Matrix: Drinking Water Lab Sample Number: 211027017-021
 Sample Location: JTMS-NS-19 Customer Sample Number:
 Sampled By: C. Anzolut
 Sample Date/Time: 1/18/2022 6:57

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	6.03	µg/L	15	1/27/2022	17:10	BM	2	1

Sample Matrix: Drinking Water Lab Sample Number: 211027017-024
 Sample Location: JTMS-TL-22 Customer Sample Number:
 Sampled By: C. Anzolut
 Sample Date/Time: 1/18/2022 7:02

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	13.8	µg/L	15	1/27/2022	17:43	BM	2	1

Sample Matrix: Drinking Water Lab Sample Number: 211027017-026
 Sample Location: Across B19 BF Customer Sample Number:
 Sampled By: C. Anzolut
 Sample Date/Time: 1/18/2022 6:12

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/27/2022	17:48	BM	2	1

Sample Matrix: Drinking Water Lab Sample Number: 211027017-027
 Sample Location: Across B19 Chiller Customer Sample Number:
 Sampled By: C. Anzolut
 Sample Date/Time: 1/18/2022 6:12

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/27/2022	17:53	BM	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 211027017-028							
Sample Location: Kitchen Front Sink		Customer Sample Number:							
Sampled By: C. Anzolut									
Sample Date/Time: 1/18/2022 6:48									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	3.49	µg/L	15	1/27/2022	17:59	BM	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 211027017-029							
Sample Location: Kitchen HW Sink		Customer Sample Number:							
Sampled By: C. Anzolut									
Sample Date/Time: 1/18/2022 6:48									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
1st Draw	SM3113B	3.33	µg/L	15	1/27/2022	18:04	BM	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 211027017-030							
Sample Location: Kitchen 3 Bay L		Customer Sample Number:							
Sampled By: C. Anzolut									
Sample Date/Time: 1/18/2022 6:48									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	3.24	µg/L	15	1/27/2022	18:21	BM	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 211027017-031							
Sample Location: Kitchen 3 Bay R		Customer Sample Number:							
Sampled By: C. Anzolut									
Sample Date/Time: 1/18/2022 6:48									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/27/2022	18:26	BM	2	1

Sample Matrix: Drinking Water Lab Sample Number: 211027017-032
 Sample Location: A Hall Boiler Rm Hall Bubbler Customer Sample Number:
 Sampled By: C. Anzolut
 Sample Date/Time: 1/18/2022 6:30

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	2.78	µg/L	15	1/27/2022	18:32	BM	2	1

Sample Matrix: Drinking Water Lab Sample Number: 211027017-033
 Sample Location: A Hall Boiler Rm Hall Chiller Customer Sample Number:
 Sampled By: C. Anzolut
 Sample Date/Time: 1/18/2022 6:30

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/27/2022	18:43	BM	2	1

Sample Matrix: Drinking Water Lab Sample Number: 211027017-034
 Sample Location: A Hall Boiler Rm Hall BF Customer Sample Number:
 Sampled By: C. Anzolut
 Sample Date/Time: 1/18/2022 6:30

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	1/27/2022	18:48	BM	2	1

Sample Matrix: Drinking Water Lab Sample Number: 211027017-035
 Sample Location: Main Office Sink Customer Sample Number:
 Sampled By: C. Anzolut
 Sample Date/Time: 1/18/2022 7:06

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	2.15	µg/L	15	1/27/2022	18:54	BM	2	1

Jefferson Township BOE

NJ Lab ID# 14013 (Dover)

NJ Lab ID# 13033 (Marlboro)

** Result does not meet NJDEP Limits.

NJDEP Limit for free and/or total chlorine does not apply to non-chlorinated samples.

Any method followed by an asterisk (*) was analyzed by the Agra-Marlboro laboratory.

All other methods, unless otherwise specified, were analyzed by the Agra-Dover laboratory.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan VanVeen

Susan VanVeen, Laboratory Manager

February 01, 2022



CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

2110270
211027017

Customer Name: Jefferson Township BOE
 Location: 1000 Weldon Road, Oak Ridge
 Address: 31 NJ-181
 Lake Hopatcong, NJ, 07849

Report to: Jefferson Township BOE
 31 NJ-181
 Lake Hopatcong, NJ, 07849
 jjahne@jefftwrp.org

Phone: Work/Cell 973-663-5780 / 973-214-6997
 973-663-5780 / 973-214-6997

Agra Environmental Services
 90 1/2 West Blackwell Street
 Dover, NJ 07801
 Phone: (973) 989-0010
 Fax: (973) 989-0156

Matrix Abbreviations: DW - Drinking water GW - Ground Water RAW-GW - Raw Ground Water WW/NPW - Wastewater SL - Sludge P - Pool L - Lake

Project: Jefferson Twp Middle School

Matrix Abbreviations: HCl Vials pH; Asc./HCl Vials pH; Na₂S₂O₈ pH; HNO₃, 2.5% pH; H₂SO₄ pH; NaOH unpreserved pH; other

Sample ID	Location	Collection	Date	Time	Preservative	# of Bottles	Matrix	Comp	Grab	PWSID#	ANALYSIS REQUESTED	Field Analysis
211027017-001	Field Blank		11/21/21	0535	HNO3	1	DW		X		Lead-1st Draw	pH / Temp
211027017-002	JTMS-POE-01		11/21/21	0526	HNO3	1	DW		X		Lead-1st Draw	Cl ₂
211027017-003	JTMS-DW-02-01 Cullen		11/21/21	0530	HNO3	1	DW		X		Lead-1st Draw	or
211027017-004	JTMS-DW-03-02 BF		11/21/21	0530	HNO3	1	DW		X		Lead-1st Draw	PO ₄
211027017-005	JTMS-DW-04-03 - Removal		11/21/21	0536	HNO3	1	DW		X		Lead-1st Draw	
211027017-006	JTMS-TL-04		11/21/21	0533	HNO3	1	DW		X		Lead-1st Draw	
211027017-007	JTMS-CT-05-01 Kit 1		11/21/21	0535	HNO3	1	DW		X		Lead-1st Draw	
211027017-008	JTMS-CT-06-02 Kit 2		11/21/21	0535	HNO3	1	DW		X		Lead-1st Draw	
211027017-009	JTMS-CT-07-03 Kit 3		11/21/21	0536	HNO3	1	DW		X		Lead-1st Draw	
211027017-010	JTMS-CT-08-04 Kit 4		11/21/21	0536	HNO3	1	DW		X		Lead-1st Draw	

Sampled By (name/company): C. Augschick/Agra

Are these samples for compliance? (circle one): Yes or **No**

Indicate laboratory location where analysis request was performed: NJDEP Laboratory Certification (Dover, NJ) #14013
 NJDEP Laboratory Certification (Marlboro, NJ) #13033

Reporting Requirements (Check Box): Standard NJ Reduced Other (Specify)

Comments: Cooler Temperature Upon Receipt at lab: N/A

Sample Custody Exchanges (Please use full legal signature)

Relinquished By: [Signature] Date: 11/22/21 Time: 10:53
 Received By: [Signature] Date: 11/22/21 Time: 11:09

Relinquished By: [Signature] Date: 11/22/21 Time: 10:53
 Received By: [Signature] Date: 11/22/21 Time: 11:09

Relinquished By: _____ Date: _____ Time: _____
 Received By: _____ Date: _____ Time: _____

Relinquished By: _____ Date: _____ Time: _____
 Received By: _____ Date: _____ Time: _____

Is sample known to be hazardous? (circle one) Yes or No

Page 13



CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

2110270
211027017

Customer Name: Jefferson Township BOE
 Location: 1000 Weldon Road, Oak Ridge
 Address: 31 NJ-181
 Lake Hopatcong, NJ, 07849

Report to: Jefferson Township BOE
 31 NJ-181
 Lake Hopatcong, NJ, 07849
 ijahnke@jefftwp.org

Customer Contact: Nick
 Phone: Work/Cell 973-663-5780 / 973-214-6997

Agra Environmental Services
 90 1/2 West Blackwell Street
 Dover, NJ 07801
 Phone: (973) 989-0010
 Fax: (973) 989-0156

Matrix Abbreviations:	DW - Drinking water	GW - Ground Water	RAW-GW - DW RAW GW	WW/NPW - Wastewater	SL - Sludge	P - Pool	L - Lake	Page 2 of 3
Project:	Jefferson Twp Middle School						for laboratory use only	Field Analysis:
Sample ID	Location	Collection	PWSID#	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED
211027017-011	JTMS-CT-09-05 Kit 5	11/8/22 0537		X	DW	1	HRD3	Lead-1st Draw
211027017-012	JTMS-CT-10-06 Island	11/8/22 0537		X	DW	1	HRD3	Lead-1st Draw
211027017-013	JTMS-CT-11-07 by Reddy	0538		X	DW	1	HRD3	Lead-1st Draw
211027017-014	JTMS-DW-12-01 R	0550		X	DW	1	HRD3	Lead-1st Draw
211027017-015	JTMS-DW-13-02 W	0550		X	DW	1	HRD3	Lead-1st Draw
211027017-016	JTMS-DW-14-03	0550		X	DW	1	HRD3	Lead-1st Draw
211027017-017	JTMS-DW-15 No Fan			X	DW	1	HRD3	Lead-1st Draw
211027017-018	JTMS-DW-16 Big Brewery	0612		X	DW	1	HRD3	Lead-1st Draw
211027017-019	JTMS-DW-17-01 Miller	0622		X	DW	1	HRD3	Lead-1st Draw
211027017-020	JTMS-DW-18-02 Brewery	0622		X	DW	1	HRD3	Lead-1st Draw

Sampled By (name/company): C. Anzalone/Agra

Are these samples for compliance? (circle one): Yes or **No**

NJDEP Laboratory Certification (Dover, NJ) #14013
 NJDEP Laboratory Certification (Marlboro, NJ) #13033

Reporting Requirements (Check Box):
 Standard
 NJ Reduced
 Other (Specify)

Indicate laboratory location where analysis request was performed:
 Cooler Temperature Upon Receipt at lab: N/A

Comments:

Sample Custody Exchanges (Please use full legal signature)


Relinquished By: Nick Date: 11/8/22 Time: 0533
 Received By: [Signature] Date: 11/8/22 Time: 0537

Relinquished By: [Signature] Date: 11/8/22 Time: 0537
 Received By: [Signature] Date: 11/8/22 Time: 0537

Relinquished By: _____ Date: _____ Time: _____
 Received By: _____ Date: _____ Time: _____

Relinquished By: _____ Date: _____ Time: _____
 Received By: _____ Date: _____ Time: _____

Date Faxed: _____ Invoice Number: _____
 Is sample known to be hazardous? (circle one) _____ Yes or No



CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

211027017

Customer Name: Jefferson Township BOE
 Location: 1000 Weldon Road, Oak Ridge
 Address: 31 NJ-181
 Lake Hopatcong, NJ, 07849

Report to: Jefferson Township BOE
 31 NJ-181
 Lake Hopatcong, NJ, 07849
 ijahnke@jefftwp.org

Agra Environmental Services
 90 1/2 West Blackwell Street
 Dover, NJ 07801
 Phone: (973) 989-0010
 Fax: (973) 989-0156

Customer Contact: Nick
 Phone: Work/Cell 973-663-5780 / 973-214-6997

Matrix Abbreviations: DW - Drinking water, GW - Ground Water, RAW-GW - DW RAW GW, WW/NPW - Wastewater, SL - Sludge
 P - Pool, L - Lake
 Page 3 of 4


Project: Jefferson Twp Middle School
 Collection: PWSID#
 for laboratory use only

Sample ID	Location	Date	Time	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	pH / Temp	Cl ₂	or	PO ₄
11027017-021	JTMS-NS-19	11/16/22	06:57	X	DW	1	HNO3	Lead-1st Draw				
11027017-022	JTMS-DW-20-01 - Remaining			X	DW	1	HNO3	Lead-1st Draw				
11027017-023	JTMS-DW-21-02			X	DW	1	HNO3	Lead-1st Draw				
11027017-024	JTMS-TL-22			X	DW	1	HNO3	Lead-1st Draw				
11027017-025	JTMS-FC-15A-23 No Location			X	DW	1	HNO3	Lead-1st Draw				
11027017-026	Access B19 BF			X	DW	1	HNO3	Lead-1st Draw				
11027017-027	" Chiller			X	DW	1	HNO3	Lead-1st Draw				
11027017-028	Kitchen Food Sink			X	DW	1	HNO3	Lead-1st Draw				
11027017-029	Kitchen HW Sink			X	DW	1	HNO3	Lead-1st Draw				
11027017-030	Kitchen 3 Bay L			X	DW	1	HNO3	Lead-1st Draw				

Sampled By (name/company): *C. Krumpal/Agra*
 Are these samples for compliance? (circle one): Yes or **No**
 Indicate laboratory location where analysis request was performed:
 NJDEP Laboratory Certification (Dover, NJ) #14013
 NJDEP Laboratory Certification (Marlboro, NJ) #130333
 Cooler Temperature Upon Receipt at lab: *2/14*

Reporting Requirements (Check Box):
 Standard NJ Reduced Other (Specify) _____

Sample Custody Exchanges (Please use full legal signature)
 Relinquished By: *[Signature]* Date: 11/16/22 Time: 10:53
 Received By: *[Signature]* Date: 11/16/22 Time: 11:02
 Relinquished By: _____ Date: _____ Time: _____
 Received By: _____ Date: _____ Time: _____
 Relinquished By: _____ Date: _____ Time: _____
 Received By: _____ Date: _____ Time: _____
 Invoice Number: _____
 Is sample known to be hazardous? (circle one) Yes or No
 Page 1 of 13



CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

211027017

Report to: Jefferson Township BOE
 31 NJ-181
 Lake Hopatcong, NJ, 07849
 jjahnke@jefftwp.org

Agra Environmental Services
 90 1/2 West Blackwell Street
 Dover, NJ 07801
 Phone: (973) 989-0010
 Fax: (973) 989-0156

Customer Name: Jefferson Township BOE
 Location: 1000 Weldon Road, Oak Ridge
 Address: 31 NJ-181
 Lake Hopatcong, NJ, 07849

Customer Contact: Nick
 Phone: Work/Cell 973-663-5780 / 973-214-6997

Matrix Abbreviations: DW - Drinking water, GW - Ground Water, RAW-GW - DW RAW GW, WW/NPW - Wastewater, SL - Sludge, P - Pool, L - Lake

Project: Jefferson Twp Middle-School

Matrix Abbreviations: Acc/HCl Vials, HCl Vials, Na2S2O8, HNO3, H2SO4, NaOH, unpreserved, other

PH: (blank)

Page 4 of 4

Sample ID	Location	Date	Time	Collection	PWSID#	Matrix	Comp	Lab	# of Bottles	Preservative	ANALYSIS REQUESTED	PH / Temp	Field Analysis
211027017-031	Kitchen 3 being R	11/22/03	0648			DW	X		1	HNO3	Lead-1st Draw		
211027017-032	11" Steel Boiler Room Hall Ceiling	0630				DW	X		1	HNO3	Lead-1st Draw		
211027017-033	" Chiller	0630				DW	X		1	HNO3	Lead-1st Draw		
211027017-034	" BF	0630				DW	X		1	HNO3	Lead-1st Draw		
211027017-035	Main Office Sink	0700				DW	X		1	HNO3	Lead-1st Draw		

Sampled By (name/company): C. Kumpel / Agra Are these samples for compliance? (circle one): Yes or **No**

NJDEP Laboratory Certification (Dover, NJ) #14013
 NJDEP Laboratory Certification (Marlboro, NJ) #13033

Reporting Requirements (Check Box): Standard NJ Reduced Other (Specify)

indicate laboratory location where analysis request was performed
 Cooler Temperature Upon Receipt at lab: N/A

Sample Custody Exchanges (Please use full legal signature)

Relinquished By: [Signature] Date: 11/22/03 Time: 11:03

Relinquished By: [Signature] Date: 11/22/03 Time: 11:03

Relinquished By: _____ Date: _____ Time: _____

Relinquished By: _____ Date: _____ Time: _____

Relinquished By: _____ Date: _____ Time: _____

Comments: _____

Date Faxed: _____ Invoice Number: _____

Is sample known to be hazardous? (circle one) Yes or No

