



## Environmental and Laboratory Services

90 ½ West Blackwell St., Dover, New Jersey 07801

(973) 989-0010 P, (973) 989-0156 F

## Analytical Results

Date: June 26, 2017

Address: Jefferson Township Middle School  
1000 Weldon Road  
Oak Ridge, NJ 07438

Project: Jefferson Township Middle School

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5681-1  
Sample location: Field Blank  
Sampled by: J. MacDonald / S. Berta / S. Flyte  
Sample date: 06/10/17  
Time: 08:38  
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/15/17	10:45	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5681-2  
Sample location: JTMS-DW-02-01-POE  
Sampled by: J. MacDonald / S. Berta / S. Flyte  
Sample date: 06/10/17  
Time: 08:47  
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/15/17	23:08	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5681-3  
Sample location: JTMS-DW-03-02  
Sampled by: J. MacDonald / S. Berta / S. Flyte  
Sample date: 06/10/17  
Time: 08:48  
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/15/17	23:14	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5681-4  
Sample location: JTMS-DW-04-03  
Sampled by: J. MacDonald / S. Berta / S. Flyte  
Sample date: 06/10/17  
Time: 08:48  
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/15/17	23:20	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5681-5  
 Sample location: JTMS-TL-04A  
 Sampled by: J. MacDonald / S. Berta / S. Flyte  
 Sample date: 06/10/17  
 Time: 08:50  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.23 µg/L	15 µg/L	06/15/17	23:26	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5681-6  
 Sample location: JTMS-CT-05-01  
 Sampled by: J. MacDonald / S. Berta / S. Flyte  
 Sample date: 06/10/17  
 Time: 09:31  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	53.6 µg/L	15 µg/L	06/15/17	23:38	4	8.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5681-7  
 Sample location: JTMS-CT-06-02  
 Sampled by: J. MacDonald / S. Berta / S. Flyte  
 Sample date: 06/10/17  
 Time: 09:32  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	5.38 µg/L	15 µg/L	06/15/17	23:57	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5681-8  
 Sample location: JTMS-CT-07-03  
 Sampled by: J. MacDonald / S. Berta / S. Flyte  
 Sample date: 06/10/17  
 Time: 09:32  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/16/17	00:03	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5681-9  
 Sample location: JTMS-CT-08-04  
 Sampled by: J. MacDonald / S. Berta / S. Flyte  
 Sample date: 06/10/17  
 Time: 09:33  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/16/17	00:09	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5681-10  
 Sample location: JTMS-CT-09-05  
 Sampled by: J. MacDonald / S. Berta / S. Flyte  
 Sample date: 06/10/17  
 Time: 09:34  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/16/17	00:15	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5681-11  
 Sample location: JTMS-CT-10-06  
 Sampled by: J. MacDonald / S. Berta / S. Flyte  
 Sample date: 06/10/17  
 Time: 09:34  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/16/17	00:21	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5681-12  
 Sample location: JTMS-CT-11-07  
 Sampled by: J. MacDonald / S. Berta / S. Flyte  
 Sample date: 06/10/17  
 Time: 09:35  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/16/17	00:27	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5681-13  
 Sample location: JTMS-DW-12-01  
 Sampled by: J. MacDonald / S. Berta / S. Flyte  
 Sample date: 06/10/17  
 Time: 08:59  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.13 µg/L	15 µg/L	06/16/17	00:33	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5681-14  
 Sample location: JTMS-DW-13-02  
 Sampled by: J. MacDonald / S. Berta / S. Flyte  
 Sample date: 06/10/17  
 Time: 09:00  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.77 µg/L	15 µg/L	06/16/17	00:39	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5681-15  
 Sample location: JTMS-DW-14-03  
 Sampled by: J. MacDonald / S. Berta / S. Flyte  
 Sample date: 06/10/17  
 Time: 09:00  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.54 µg/L	15 µg/L	06/16/17	00:45	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5681-16  
 Sample location: JTMS-FC-15  
 Sampled by: J. MacDonald / S. Berta / S. Flyte  
 Sample date: 06/10/17  
 Time: 09:16  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/16/17	00:51	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5681-17  
 Sample location: JTMS-DW-16  
 Sampled by: J. MacDonald / S. Berta / S. Flyte  
 Sample date: 06/10/17  
 Time: 09:17  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/16/17	01:03	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5681-18  
 Sample location: JTMS-DW-17-01  
 Sampled by: J. MacDonald / S. Berta / S. Flyte  
 Sample date: 06/10/17  
 Time: 09:18  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.24 µg/L	15 µg/L	06/16/17	01:10	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5681-19  
 Sample location: JTMS-FC-18-02  
 Sampled by: J. MacDonald / S. Berta / S. Flyte  
 Sample date: 06/10/17  
 Time: 09:19  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/16/17	01:16	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5681-20  
 Sample location: JTMS-NS-19  
 Sampled by: J. MacDonald / S. Berta / S. Flyte  
 Sample date: 06/10/17  
 Time: 09:20  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.97 µg/L	15 µg/L	06/16/17	01:28	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5681-21  
 Sample location: JTMS-DW-20-01  
 Sampled by: J. MacDonald / S. Berta / S. Flyte  
 Sample date: 06/10/17  
 Time: 09:23  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/16/17	01:52	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5681-22  
 Sample location: JTMS-DW-21-02  
 Sampled by: J. MacDonald / S. Berta / S. Flyte  
 Sample date: 06/10/17  
 Time: 09:23  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.03 µg/L	15 µg/L	06/16/17	01:58	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5681-23  
Sample location: JTMS-TL-22  
Sampled by: J. MacDonald / S. Berta / S. Flyte  
Sample date: 06/10/17  
Time: 09:28  
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.07 µg/L	15 µg/L	06/16/17	02:04	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5681-24  
Sample location: JTMS-FC-15A-23  
Sampled by: J. MacDonald / S. Berta / S. Flyte  
Sample date: 06/10/17  
Time: 09:17  
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/16/17	02:09	1	2.00 µg/L

µg/L = micrograms per liter

**Field Notes:**

**Automatic flushing toilet system in operation at time of sampling**

All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Laurette Yang (For SV)  
Susan VanVeen, Lab Manager  
NJ Laboratory Certification ID # 14013

July 8, 2017  
Date

# CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

# \_\_\_\_\_ Asc./HCl Vials pH: \_\_\_\_\_  
 # \_\_\_\_\_ HCl Vials pH: \_\_\_\_\_  
 # \_\_\_\_\_ Na<sub>2</sub>S<sub>2</sub>O<sub>3</sub> Cl<sub>2</sub>: \_\_\_\_\_  
 # 24 HNO<sub>3</sub> (250 mL) pH: C2  
 # \_\_\_\_\_ H<sub>2</sub>SO<sub>4</sub> pH: \_\_\_\_\_  
 # \_\_\_\_\_ NaOH pH: \_\_\_\_\_  
 # \_\_\_\_\_ unpreserved \_\_\_\_\_  
 # \_\_\_\_\_ other \_\_\_\_\_  
 # \_\_\_\_\_ other \_\_\_\_\_


Customer Name: Jefferson Township Middle School	report to:	Agra Environmental Services
Address: 1000 Weldon Road		90½ West Blackwell Street
Oak Ridge NJ 07438		Dover, NJ 07801
County/Municipality:		Phone: (973) 989-0010
Phone: 973-697-1980		Fax: (973) 989-0156
Work:		

Matrix Abbreviations: D - Drinking Water G- Groundwater W- Wastewater S- Soil SL- Sludge P-Pool L-Lake


Project:		Collection		PWSID# NJ					for laboratory use only		Field Analysis	
Field ID	Lab ID:	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED			
DWS5681												
Field Blank	-1	6/10/17	0838	X			1	HNO <sub>3</sub>	1st Draw Pb 2.00 ug/L 6/15/17 1045 AM			
JTMS-POE-01									1st Draw Pb No OUTLET - Port of Hs			
JTMS-DW-02-01 - POE	-2		0847						1st Draw Pb 2.00 ug/L 6/15/17 2308 PM			
JTMS-DW-03-02	-3		0848						1st Draw Pb 2.00 2314			
JTMS-DW-04-03	-4		0848						1st Draw Pb 2.00 2320			
JTMS-TL-04 A	-5		0850						1st Draw Pb 2.23 2326			
JTMS-CT-05-01	-6		0931						1st Draw Pb 5.26 2338		1:4	
JTMS-CT-06-02	-7		0934						1st Draw Pb 5.38 2357			
JTMS-CT-07-03	-8		0934						1st Draw Pb 2.00 6/16/17 0003			
JTMS-CT-08-04	-9		0933						1st Draw Pb 2.00 6/16/17 0009			
Sampled By (name/company):		State Forms Needed (circle one): Yes or No							indicate laboratory location where analysis requested was performed			
SM / SB / SF		NJDEP Laboratory Certification (Dover, NJ) #14013										
		NJDEP Laboratory Certification (Marlboro, NJ) #13033										
Reporting Requirements (Check Box):		Standard		NJ Reduced		Other (Specify)			Cooler Temperature Upon Receipt at lab:			
Sample Custody Exchanges (Please use full legal signature)										Scanned _____		
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	toilet flushing.						
Relinquished By:	Date:	Time:	Received By:	Date:	Time:							
Relinquished By:	Date:	Time:	Received By:	Date:	Time:							
Relinquished By:	Date:	Time:	Received By:	Date:	Time:							
Date Faxed _____										Invoice Number _____		
Is sample known to be hazardous? (circle one)										Yes or No		



# CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Customer Name: Jefferson Township Middle School		report to:		Agra Environmental Services	
Address: 1000 Weldon Road				90½ West Blackwell Street	
Oak Ridge NJ 07438				Dover, NJ 07801	
County/Municipality:				Phone: (973) 989-0010	
Phone: 973-697-1980				Fax: (973) 989-0156	
Work:					
Matrix Abbreviations: D - Drinking Water   G- Groundwater   W- Wastewater   S- Soil   SL- Sludge   P-Pool   L-Lake   Page <u>1</u> of <u>1</u>					
Project:		Collection		PWSID# NJ	
				for laboratory use only	
Lab ID:				Field Analysis	
Field ID		Date	Time	Grab	Comp
				Matrix	# of Bottles
				Preservative	
				ANALYSIS REQUESTED	
JTMS-CT-09-05	-10	6/10/17	0934	X	
JTMS-CT-10-06	-11		0934		
JTMS-CT-11-07	-12		0935		
JTMS-DW-12-01	-13		0859		
JTMS-DW-13-02	-14		0900		
JTMS-DW-14-03	-15		0900		
JTMS-DW-15-FC	-16		0916		
JTMS-DW-16	-17		0917		
JTMS-DW-17-01	-18		0918		
JTMS-DW-18-02 FC	-19		0919		
1st Draw Pb 2.00 ug/L		6/16/17		0015 BA	
1st Draw Pb 2.00				0031	
1st Draw Pb 2.00				0037	
1st Draw Pb 3.13				0033	
1st Draw Pb 2.77				0039	
1st Draw Pb 3.54				0045	
1st Draw Pb 2.00				0051	
1st Draw Pb 2.00				0103	
1st Draw Pb 3.24				0110	
1st Draw Pb 2.00				0116	
Sampled By (name/company):		State Forms Needed (circle one): Yes or No		indicate laboratory location where analysis requested was performed	
JM/SB/SF		NJDEP Laboratory Certification (Dover, NJ) #14013			
		NJDEP Laboratory Certification (Marlboro, NJ) #13033			
Reporting Requirements (Check Box):		Standard	NJ Reduced	Other (Specify)	Cooler Temperature Upon Receipt at lab:
Sample Custody Exchanges (Please use full legal signature)					Scanned _____
Relinquished By:	Date:	Time:	Received By:	Date:	Time:
Cherry Puffo	6/14/17	1103	[Signature]	6/17/17	1104
Relinquished By:	Date:	Time:	Received By:	Date:	Time:
Relinquished By:	Date:	Time:	Received By:	Date:	Time:
Relinquished By:	Date:	Time:	Received By:	Date:	Time:
Date Faxed _____					
Invoice Number _____					
Is sample known to be hazardous? (circle one)					
Yes or No					

# CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Customer Name: Jefferson Township Middle School	report to:	<b>Agra Environmental Services</b> 90½ West Blackwell Street Dover, NJ 07801 Phone: (973) 989-0010 Fax: (973) 989-0156 
Address: 1000 Weldon Road		
Oak Ridge NJ 07438		
County/Municipality:		
Phone: 973-697-1980		
Work:		

Matrix Abbreviations: D - Drinking Water G- Groundwater W- Wastewater S- Soil SL- Sludge P-Pool L-Lake Page 1 of 1

Project:		Collection		PWSID# NJ					for laboratory use only		Field Analysis	
Lab ID:				Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED			
Field ID		Date	Time									
DW55681		6/10/17	0920	X			1	H/NC <sub>3</sub>	1st Draw Pb 2.47 ug/L 6/16/17 0128		3M	
JTMS-NS-19		6/10/17	0923				1		1st Draw Pb 2.00 ug/L 6/16/17 0152		3M	
JTMS-DW-20-01		6/10/17	0923				1		1st Draw Pb 2.03 0158			
JTMS-DW-21-02		6/10/17	0928				1		1st Draw Pb 2.07 0204			
JTMS-TL-22		6/10/17	0917				1		1st Draw Pb 2.00 0209			
JTMS FC - ISA 23									1st Draw Pb			
									1st Draw Pb			
									1st Draw Pb			
									1st Draw Pb			
									1st Draw Pb			

Sampled By (name/company): SM/SB/SE	State Forms Needed (circle one): Yes or No				indicate laboratory location where analysis requested was performed			
	NJDEP Laboratory Certification (Dover, NJ) #14013							
	NJDEP Laboratory Certification (Marlboro, NJ) #13033							
Reporting Requirements (Check Box):	Standard	NJ Reduced	Other (Specify)		Cooler Temperature Upon Receipt at lab:			

Sample Custody Exchanges (Please use full legal signature)						Scanned _____	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:		
Relinquished By:	Date:	Time:	Received By:	Date:	Time:		
Relinquished By:	Date:	Time:	Received By:	Date:	Time:		
Relinquished By:	Date:	Time:	Received By:	Date:	Time:		
Date Faxed _____						Invoice Number _____	
Is sample known to be hazardous? (circle one)						Yes or No	



Name of School: Jefferson Township Middle School Address: 1000 Weldon Road Oak Ridge, NJ 07438Grade Levels: 6 – 8 Year School Constructed: \_\_\_\_\_ Renovated/Additions: \_\_\_\_\_

Individual school project officer Name/Signature: \_\_\_\_\_ Date Completed: \_\_\_\_\_

# <sup>6</sup>	Type	Location	Code	Operational <sup>7</sup> (Y/N)	Signs of Corrosion <sup>8</sup> (Y/N)	Filter <sup>9</sup> (Y/N)	Brass Fittings, Faucets or valves? (Y/N)	Aerator/ Screen (Y/N)	Motion Activated (Y/N)	Chiller (Y/N)	Water Cooler		Comments
											Make	Model	
01	POE	WTR TANK RM	JTMS-POE-01	Y	N	N	Y	Y	N	N			
01a	DW	ACROSS B26 - POE	JTMS-DW-02-01 - POE	Y	N	N	Y	Y	N	N			
02	DW	ACROSS B26	JTMS-DW-03-02	Y	N	N	Y	Y	N	N			
03	DW	ACROSS B26	JTMS-DW-04-03	Y	N	N	Y	Y	N	N			
04	TL	B25	JTMS-TL-04	Y	N	N	Y	Y	N	N			
05	CT	B28	JTMS-CT-05-01	Y	N	N	Y	Y	N	N			
06	CT	B28	JTMS-CT-06-02	Y	N	N	Y	Y	N	N			
07	CT	B28	JTMS-CT-07-03	Y	N	N	Y	Y	N	N			
08	CT	B28	JTMS-CT-08-04	Y	N	N	Y	Y	N	N			
09	CT	B28	JTMS-CT-09-05	Y	N	N	Y	Y	N	N			
10	CT	B28	JTMS-CT-10-06	Y	N	N	Y	Y	N	N			
11	CT	B28	JTMS-CT-11-07	Y	N	N	Y	Y	N	N			
12	DW	BY RM B6	JTMS-DW-12-01	Y	N	N	Y	Y	N	N			
13	DW	BY RM B6	JTMS-DW-13-02	Y	N	N	Y	Y	N	N			

<sup>6</sup> Number outlets starting at the closest outlet to the Point of Entry (POE).<sup>7</sup> Document if permanently or temporarily out of service on the Attachment B- Plumbing Profile.<sup>8</sup> Signs of corrosion detected, such as but not limited to frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry.<sup>9</sup> Document on Attachment D- Filter Inventory.

Jefferson Township School District Sampling Plan

May 25, 2017

Version 1

14	DW	BY RM B6	JTMS-DW-14-03	Y	N	N	N	N	Y	N	Y	
15	DW	ACROSS B9	JTMS-DW-15 FC-ISA	Y	N	N	N	N	Y	N	Y	
16	DW	ACROSS B19	JTMS-DW-16	Y	N	N	N	N	Y	N	Y	
17	DW	ACROSS A310	JTMS-DW-17-01	Y	N	N	N	N	Y	N	Y	
18	DW	ACROSS 310	JTMS-DW-18-02 SC	Y	N	N	N	N	Y	N	Y	
19	NS	ROOM A310	JTMS-NS-19	Y	N	N	N	N	Y	N	Y	
20	DW	ACROSS C10	JTMS-DW-20-01	Y	N	N	N	N	Y	N	Y	
21	DW	ACROSS C10	JTMS-DW-21-02	Y	N	N	N	N	Y	N	Y	
22	TL	C3A	JTMS-TL-22	Y	N	N	N	N	Y	N	Y	