

Jefferson Middle School (PWSID#: NJ1414419)

1000 Weldon Road, Oak Ridge, NJ 07438

Year 2022 Annual Water Quality Report

What's The Quality of Your Water?

Jefferson Board of Education is proud to supply you with this year's Water Quality Report required by the State of New Jersey Department of Environmental Protection (NJDEP) and the U.S. Environmental Protection Agency (EPA). The tables in this report show the results of our water quality analysis in the year 2022. Every regulated contaminant detected in the water, even in the minutest traces, is listed. The table contains the name of each highest level allowed by regulation (MCL), the ideal goals for public health (MCLG), usual sources of such contamination, definitions that explain what was tested, and a key to the units of measurement. *The data tables in this report show only the substances **detected** in your water; other substances may have been tested and not detected.*

Jefferson Middle School received no violations in 2022. The EPA requires monitoring for over 80 drinking water contaminants. The contaminants listed in the table on the next page reflect only the contaminants detected in your water for the monitoring period January 1 to December 31, 2022. We routinely monitor for contaminants in your drinking water according to federal and state laws. The state allows us to monitor for some contaminants less than once per year because the concentrations of those contaminants do not change frequently. Some of our data, though representative, may be more than one year old.

Sources of Supply

Jefferson Township Middle School takes its water from a ground water well located near the school. The well is chlorinated and serves an average of 900 people per day.

GENERAL DRINKING WATER INFORMATION:

Water Sources

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Biological* - may come from human, agricultural, or wildlife sources.
- *Inorganic* - can be natural, from storm run-off, or from industrial or domestic wastewater discharges.
- *Pesticides and herbicides* - may come from agricultural, storm run-off or residential use.
- *Organic chemicals* - may come from industrial or domestic processes, storm run-off, and septic systems.
- *Radioactive materials* - can be naturally occurring or the result of mining or other human activities.

Presence of Contaminants

The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (1-800-426-4791). In order to ensure that tap water is safe to drink, the EPA prescribes regulations that limit the amounts of certain contaminants in water provided by public water systems.

Immuno-Compromised Persons

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

JEFFERSON MIDDLE SCHOOL WATER QUALITY TABLE

| Contaminant | MCL Violation Y/N | Level Detected via # of Samples | Unit of Measurement | MCL (Highest Level Allowed) | MCLG (Goal) | Potential Source |
|---|-------------------|--|---------------------|-----------------------------|-------------|--|
| Lead Test Results Year: 2020 | N | 3.8 (90 th Percentile) Range: ND-3.8 0>AL | ppb | 15 (Action Limit) | 0 | Corrosion of household plumbing |
| Copper Test Results Year: 2020 | N | 0.2 (90 th Percentile) Range: 0.07-0.28 0>AL | ppm | 1.3 (Action Limit) | 1.3 | Corrosion of household plumbing |
| Barium Test Results Year: 2022 | N | 0.02 1 Sample | ppm | 2 | 2 | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits |
| Chromium Test Results Year: 2022 | N | 1.5 1 Sample | ppb | 100 | 100 | Discharge from steel and pulp mills; erosion of natural deposits |
| Nickel Test Results Year: 2022 | N | 1.1 1 Sample | ppb | N/A | N/A | Erosion of natural deposits; found in the earth's crust |
| THM Stage 2 Test Results Year: 2022 | N | Highest LRAA: 0.6 Range: ND – 1.3 | ppb | 80 | N/A | Disinfectant Byproducts |
| Chlorine Residual Test Results Year: 2022 | N | Average: 0.29 Range: 0.05 – 0.49 | ppm | MRDL 4 | MRDLG 4 | Water additive used to control microbes |

Radiologicals

| Contaminant | MCL Violation Y/N | Average Detected Level via # of Samples | Unit of Measurement | MCL | MCLG | Potential Source |
|---|-------------------|---|---------------------|-----|------|-----------------------------|
| Gross Alpha Test Results Year: 2019 | N | 2.7 4 Samples | pCi/L | 15 | 0 | Erosion of natural deposits |
| Combined Radium Test Results Year: 2019 | N | 0.3 4 Samples | pCi/L | 5 | 0 | Erosion of natural deposits |

Secondary Contaminants

| Contaminant | Average Level Detected | Range of Detections | Unit of Measurement | RUL | Potential Source |
|----------------|------------------------|---------------------|---------------------|-----|---------------------|
| Sodium (2022) | 70 | 1 Sample | ppm | 50 | Naturally Occurring |
| Sulfate (2022) | 9 | 1 Sample | ppm | 250 | Naturally Occurring |

Special note regarding Sodium: For healthy individuals, the sodium intake from water is not important, because a much greater intake of sodium takes place from salt in the diet. However, sodium levels above the recommended limit may be a concern to individuals on a sodium restricted diet.

How to read this report:

| Word, Acronym, Symbol or Note | Definition |
|--------------------------------------|---|
| Y/N | Yes/No |
| AL | Action Level. The concentration of a contaminant, which, if exceeded, triggers a treatment or other requirements, which a water system must follow. |
| CDC | Centers for Disease Control |
| EPA | United States Environmental Protection Agency. |
| LRAA | Locational Running Annual Average |
| MCL | Maximum Contaminant Level. The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. |
| MCLG | Maximum Contaminant Level Goal. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. |
| MRDL | Maximum Residual Disinfectant Level – The highest level of a disinfectant allowed in drinking water. |
| MRDLG | Maximum Residual Disinfectant Level Goal – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants. |
| N/A | Not applicable |
| NJDEP | New Jersey Department of Environmental Protection |
| ND | Not detected |
| ppb | Parts per billion. Means 1 part per 1,000,000,000 (same as micrograms per liter) and correspond to 1 penny in \$10 million. |
| ppm | Parts per million. Means 1 part per 1,000,000 parts (same as milligrams per liter) and corresponds to 1 penny in \$10,000. |
| RUL | Recommended Upper Limit |

Health Effects of Detected Contaminants:

Barium: Barium is a naturally occurring ore used in a variety of manufactured goods. The EPA has found that in some people, short exposure to Barium in exceedance of the MCL can cause gastrointestinal disturbances and muscle weakness. Long term exposure to barium at levels above the MCL may cause high blood pressure.

Chromium: Some people who use water containing chromium well in excess of the MCL over many years could experience allergic dermatitis.

Chlorine: Some people who use water containing chlorine well in excess of the MRDL could experience irritating effects to their eyes and nose. Some people who drink water containing chlorine well in excess of the MRDL could experience stomach discomfort.

Copper: Copper is an essential nutrient, but some people who drink water that contains copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water that contains copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilsons Disease should consult their personal doctor.

Gross Alpha (48 Hour): Certain minerals are radioactive and may emit a form of radiation known as alpha radiation. Some people who drink water containing alpha emitters in excess of the MCL over many years may have an increased risk of getting cancer.

Lead: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Jefferson Twp BOE is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. (Revised 1/10/2022)

Nickel: Some people who drink water containing nickel in excess of the MCL over many years may experience liver effects.

Radium: Some people who drink water containing radium 226 or 228 in excess of the MCL over many years may have an increased risk of getting cancer.

Secondary Contaminant: These parameters do not have an impact on health. Secondary Contaminants affect aesthetic qualities such as odor, taste or appearance. Secondary standards are recommendations, not mandates.

Sodium (Na): Naturally occurring mineral. Sodium is essential for good health. Certain medical conditions, however, require sodium intake monitoring. Excessive sodium can adversely affect high blood pressure, heart disease or diabetes. Contact your physician for further information.

Sulfate: Sulfate occurs naturally in water and is monitored as a secondary contaminant. Secondary contaminants are aesthetic (taste and odor) rather than health risks; however, in high concentrations sulfate can cause Diarrhea in some people.

THMs (Trihalomethanes): Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

Source Water Assessment

The New Jersey Department of Environmental Protection (NJDEP) has completed and issued the Source Water Protection Report and Summary for this public water system, which is available at www.nj.gov/dep/watersupply/swap/creport.htm or by contacting the NJDEP, Bureau of Safe Drinking Water at 609-292-5550.

The table below illustrates the susceptibility rating for each individual source for each of the contaminant categories at this water system. For susceptibility ratings of purchased water, refer to the specific water system’s source water assessment report. NJDEP considered all surface water highly susceptible to pathogens. For the purpose of the Source Water Assessment Program, radionuclides are more of a concern for ground water than surface water. If the system is rated highly susceptible for a contaminant category, it does not mean that a customer is or will be consuming contaminated drinking water. The rating reflects the potential for contamination of source water, not the existence of contamination. Public water systems are required to monitor for regulated contaminants and to install treatment if any contaminants are detected at frequencies and concentrations above allowable levels. As a result of the assessments, NJDEP may customize (change existing) monitoring schedules based on the susceptibility ratings. If you have questions regarding the source water assessment report or summary, please contact the Bureau of Safe Drinking Water at 609-252-5550.

| <u>Source Name</u> | <u>Pathogens</u> | <u>Nutrients</u> | <u>Pesticides</u> | <u>VOCs</u> | <u>Inorganics</u> | <u>Radionuclides</u> | <u>Radon</u> | <u>DBPs</u> |
|--------------------|------------------|------------------|-------------------|---------------|-------------------|----------------------|---------------|---------------|
| | <i>Rating</i> | <i>Rating</i> | <i>Rating</i> | <i>Rating</i> | <i>Rating</i> | <i>Rating</i> | <i>Rating</i> | <i>Rating</i> |
| Well 1 | L | L | L | H | L | M | M | H |

Susceptibility ratings for a public water system are based on the potential for a contaminant to be:

- At or above 50% of the Drinking Water Standard (MCL) = **(H) High**
- Between 10 and 50% of the Drinking Water Standard (MCL) = **(M) Medium**
- Less than 10% of the Drinking Water Standard (MCL) = **(L) Low**

Pathogens: Disease-causing organisms such as bacteria and viruses. Common sources are animal and human fecal wastes.

Nutrients: Compounds, minerals and elements that aid growth, and are both naturally occurring and man-made. Examples include nitrogen and phosphorus.

Volatile Organic Compounds (VOCs): Man-made chemicals used as solvents, degreasers, and gasoline components. Examples include benzene, methyl tertiary butyl ether (MTBE), and vinyl chloride.

Pesticides: Man-made chemicals used to control pests, weeds and fungus. Common sources include land application and manufacturing centers of pesticides. Examples include herbicides such as atrazine, and insecticides such as chlordane.

Inorganics: Mineral-based compounds that are both naturally occurring and man-made. Examples include arsenic, asbestos, copper, lead, and nitrate.

Radionuclides: Radioactive substances that are both naturally occurring and man-made. Examples include radium and uranium.

Radon: Colorless, odorless, cancer-causing gas that occurs naturally in the environment. For more information go to <http://www.nj.gov/dep/rpp/radon/index.htm> or call 800-648-0394.

(DBPs) Disinfectant Byproduct Precursors: A common source is naturally occurring organic matter in surface water. Disinfection byproducts are formed when other disinfectants (usually chlorine) used to kill pathogens react with dissolved organic material (for example leaves) present in surface water.

This Water Quality Report was prepared for Jefferson Middle School by:

