



Environmental and Laboratory Services

Dover Location:
90 1/2 West Blackwell St., Dover, NJ 07801
Phone: (973) 989-0010, Fax (973) 989-0156

Marlboro Location:
8A Railroad Ave, Marlboro, NJ 07746
Phone: (732) 308-3500, Fax (732) 308-3503

Date: December 08, 2023
Client: Jefferson High School
Address: 1010 Weldon Rd
Oak Ridge, NJ 07438

PWSID#: NJ1414401

Project Location:

Analytical Results

Table with 10 columns: Parameters, Method, Results, Units, NJDEP Limit, Date Analyzed, Time Analyzed, Analyst, Reporting Limit, Dilution Factor. Rows include Total Coliform, E. Coli, and Free Chlorine.

NJ Lab ID# 14013 (Dover)
NJ Lab ID# 13033 (Marlboro)

NJDEP Limit for free and/or total chlorine does not apply to non-chlorinated samples.
Any method followed by an asterisk (*) was analyzed by the Agra-Marlboro laboratory.
All other methods, unless otherwise specified, were analyzed by the Agra-Dover laboratory.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Michael J Furrey, President



Environmental and Laboratory Services

Dover Location:
90 1/2 West Blackwell St., Dover, NJ 07801
Phone: (973) 989-0010, Fax (973) 989-0156

Marlboro Location:
8A Railroad Ave, Marlboro, NJ 07746
Phone: (732) 308-3500, Fax (732) 308-3503

Date: December 13, 2023
Client: Jefferson High School
Address: 1010 Weldon Rd
Oak Ridge, NJ 07438

PWSID#: NJ1414401

Project Location:

Analytical Results

Sample Matrix: Drinking Water Lab Sample Number: 231114030-001
Sample Location: New Kit Food Prep 1 PBCU10 Customer Sample Number:
Sampled By: B. Jack
Sample Date/Time: 11/15/2023 5:04

Table with 10 columns: Parameters, Method, Results, Units, NJDEP Limit, Date Analyzed, Time Analyzed, Analyst, Reporting Limit, Dilution Factor. Rows include Copper-1st Draw and Lead-1st Draw.

Sample Matrix: Drinking Water Lab Sample Number: 231114030-002
Sample Location: New Kit Food Prep 2 PBCU31 Customer Sample Number:
Sampled By: B. Jack
Sample Date/Time: 11/15/2023 5:05

Table with 10 columns: Parameters, Method, Results, Units, NJDEP Limit, Date Analyzed, Time Analyzed, Analyst, Reporting Limit, Dilution Factor. Rows include Copper-1st Draw and Lead-1st Draw.

Sample Matrix: Drinking Water **Lab Sample Number:** 231114030-003
Sample Location: New Kit Food Prep 3 PBCU32 **Customer Sample Number:**
Sampled By: B. Jack
Sample Date/Time: 11/15/2023 5:06

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Copper-1st Draw	EPA200.8	710	µg/L	1300	12/6/2023	15:32	BM	40	1
Lead-1st Draw	EPA200.8	< 1.00	µg/L	15	12/6/2023	15:32	BM	1	1

Sample Matrix: Drinking Water **Lab Sample Number:** 231114030-004
Sample Location: New Kit Food Prep 4 PBCU33 **Customer Sample Number:**
Sampled By: B. Jack
Sample Date/Time: 11/15/2023 5:07

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Copper-1st Draw	EPA200.8	721	µg/L	1300	12/6/2023	15:51	BM	40	1
Lead-1st Draw	EPA200.8	< 1.00	µg/L	15	12/6/2023	15:51	BM	1	1

Sample Matrix: Drinking Water **Lab Sample Number:** 231114030-005
Sample Location: New Kit 2 Bay PBCU26 **Customer Sample Number:**
Sampled By: B. Jack
Sample Date/Time: 11/15/2023 5:00

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Copper-1st Draw	EPA200.8	396	µg/L	1300	12/6/2023	15:56	BM	40	1
Lead-1st Draw	EPA200.8	< 1.00	µg/L	15	12/6/2023	15:56	BM	1	1

Sample Matrix: Drinking Water **Lab Sample Number:** 231114030-006
Sample Location: Old Kit Coffee Sink PBCU11 **Customer Sample Number:**
Sampled By: B. Jack
Sample Date/Time: 11/15/2023 4:55

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Copper-1st Draw	EPA200.8	270	µg/L	1300	12/6/2023	16:01	BM	40	1
Lead-1st Draw	EPA200.8	<1.00	µg/L	15	12/6/2023	16:01	BM	1	1

Sample Matrix: Drinking Water **Lab Sample Number:** 231114030-007
Sample Location: Old Kit Left 3-Bay PBCU12 **Customer Sample Number:**
Sampled By: B. Jack
Sample Date/Time: 11/15/2023 4:57

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Copper-1st Draw	EPA200.8	189	µg/L	1300	12/6/2023	16:06	BM	40	1
Lead-1st Draw	EPA200.8	9.97	µg/L	15	12/6/2023	16:06	BM	1	1

Sample Matrix: Drinking Water **Lab Sample Number:** 231114030-008
Sample Location: Home Ec Sink 1 PBCU3 **Customer Sample Number:**
Sampled By: B. Jack
Sample Date/Time: 11/15/2023 5:13

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Copper-1st Draw	EPA200.8	177	µg/L	1300	12/6/2023	16:10	BM	40	1
Lead-1st Draw	EPA200.8	<1.00	µg/L	15	12/6/2023	16:10	BM	1	1

Sample Matrix: Drinking Water **Lab Sample Number:** 231114030-009
Sample Location: Home Ec Sink 2 PBCU13 **Customer Sample Number:**
Sampled By: B. Jack
Sample Date/Time: 11/15/2023 5:14

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Copper-1st Draw	EPA200.8	262	µg/L	1300	12/6/2023	16:15	BM	40	1
Lead-1st Draw	EPA200.8	2.65	µg/L	15	12/6/2023	16:15	BM	1	1

Sample Matrix: Drinking Water **Lab Sample Number:** 231114030-010
Sample Location: Home Ec Sink 3 PBCU14 **Customer Sample Number:**
Sampled By: B. Jack
Sample Date/Time: 11/15/2023 5:15

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Copper-1st Draw	EPA200.8	428	µg/L	1300	12/6/2023	16:20	BM	40	1
Lead-1st Draw	EPA200.8	< 1.00	µg/L	15	12/6/2023	16:20	BM	1	1

Sample Matrix: Drinking Water **Lab Sample Number:** 231114030-011
Sample Location: Home Ec Sink 4 PBCU15 **Customer Sample Number:**
Sampled By: B. Jack
Sample Date/Time: 11/15/2023 5:16

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Copper-1st Draw	EPA200.8	278	µg/L	1300	12/6/2023	16:25	BM	40	1
Lead-1st Draw	EPA200.8	< 1.00	µg/L	15	12/6/2023	16:25	BM	1	1

Sample Matrix: Drinking Water **Lab Sample Number:** 231114030-012
Sample Location: Home Ec Sink 5 PBCU22 **Customer Sample Number:**
Sampled By: B. Jack
Sample Date/Time: 11/15/2023 5:17

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Copper-1st Draw	EPA200.8	466	µg/L	1300	12/6/2023	16:30	BM	40	1
Lead-1st Draw	EPA200.8	< 1.00	µg/L	15	12/6/2023	16:30	BM	1	1

Sample Matrix: Drinking Water **Lab Sample Number:** 231114030-013
Sample Location: Home Ec Sink 6 PBCU25 **Customer Sample Number:**
Sampled By: B. Jack
Sample Date/Time: 11/15/2023 5:18

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Copper-1st Draw	EPA200.8	426	µg/L	1300	12/6/2023	16:35	BM	40	1
Lead-1st Draw	EPA200.8	< 1.00	µg/L	15	12/6/2023	16:35	BM	1	1

Sample Matrix: Drinking Water **Lab Sample Number:** 231114030-014
Sample Location: R WF by Life Skills PBCU9 **Customer Sample Number:**
Sampled By: B. Jack
Sample Date/Time: 11/15/2023 5:26

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Copper-1st Draw	EPA200.8	268	µg/L	1300	12/6/2023	17:03	8M	40	1
Lead-1st Draw	EPA200.8	< 1.00	µg/L	15	12/6/2023	17:03	8M	1	1

Sample Matrix: Drinking Water **Lab Sample Number:** 231114030-015
Sample Location: L WF by Life Skills PBCU20 **Customer Sample Number:**
Sampled By: B. Jack
Sample Date/Time: 11/15/2023 5:25

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Copper-1st Draw	EPA200.8	324	µg/L	1300	12/6/2023	17:08	BM	40	1
Lead-1st Draw	EPA200.8	< 1.00	µg/L	15	12/6/2023	17:08	BM	1	1

Sample Matrix: Drinking Water **Lab Sample Number:** 231114030-016
Sample Location: Nurse Office PBCU4 **Customer Sample Number:**
Sampled By: B. Jack
Sample Date/Time: 11/15/2023 5:38

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Copper-1st Draw	EPA200.8	355	µg/L	1300	12/6/2023	17:13	BM	40	1
Lead-1st Draw	EPA200.8	< 1.00	µg/L	15	12/6/2023	17:13	BM	1	1

Sample Matrix: Drinking Water **Lab Sample Number:** 231114030-017
Sample Location: Right WF by Nurse PBCU5 **Customer Sample Number:**
Sampled By: B. Jack
Sample Date/Time: 11/15/2023 5:36

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Copper-1st Draw	EPA200.8	95.6	µg/L	1300	12/6/2023	17:37	BM	40	1
Lead-1st Draw	EPA200.8	< 1.00	µg/L	15	12/6/2023	17:37	BM	1	1

Sample Matrix: Drinking Water **Lab Sample Number:** 231114030-018
Sample Location: Faculty Room E13 PBCU2 **Customer Sample Number:**
Sampled By: B. Jack
Sample Date/Time: 11/15/2023 5:30

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Copper-1st Draw	EPA200.8	338	µg/L	1300	12/6/2023	17:42	BM	40	1
Lead-1st Draw	EPA200.8	< 1.00	µg/L	15	12/6/2023	17:42	BM	1	1

Sample Matrix: Drinking Water **Lab Sample Number:** 231114030-019
Sample Location: Teacher Lounge A11 PBCU1 **Customer Sample Number:**
Sampled By: B. Jack
Sample Date/Time: 11/15/2023 5:43

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Copper-1st Draw	EPA200.8	234	µg/L	1300	12/6/2023	17:47	BM	40	1
Lead-1st Draw	EPA200.8	1.15	µg/L	15	12/6/2023	17:47	BM	1	1

Sample Matrix: Drinking Water **Lab Sample Number:** 231114030-020
Sample Location: Ticket Booth Sink DS **Customer Sample Number:**
Sampled By: B. Jack
Sample Date/Time: 11/15/2023 5:33

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Copper-1st Draw	EPA200.8	299	µg/L	1300	12/6/2023	17:52	BM	40	1
Lead-1st Draw	EPA200.8	< 1.00	µg/L	15	12/6/2023	17:52	BM	1	1